

PROVINCIAL NOTICE 52 OF 2021

CITY OF MBOMBELA



FIRE BRIGADE BY- LAW

**CITY OF MBOMBELA
FIRE BRIGADE BY-LAW**

Table of Contents

Volume 1	6
APPLICATION AND INTERPRETATION OF BY-LAWS	6
1. Application of By-laws	6
2. Definitions and Interpretation	6
Volume 2	10
FIRE PREVENTION AND FIRE PROTECTION	10
Part 1: Fire Prevention	10
3. Certain fires prohibited	10
4. 1. Storage and accumulation of combustible material prohibited	11
5. Electrical fittings, equipment and appliances	12
6.1. Flame-emitting devices.....	12
7. Safety fire-breaks required.....	13
Part 2: Fire Protection	13
8. Design and construction of buildings.....	13
9. Design and construction of dumping sites	14
10. Design and construction of other structures and sites	14
11. Requirements for sprinkler systems	15
12. Requirements for extractor fan systems.....	15
13. Requirements for emergency exits.....	16
14. Design, identification and access for fire-fighting and rescue purposes.....	16
15. Barricading of vacant buildings	17
Part 3: Fire Fighting Equipment and Emergency Evacuation Plans	17
16. Installation and maintenance of fire-fighting equipment	17
17. Chief Fire Officer may designate premises for emergency evacuation plans.....	18
18. Duties of owner or occupier of designated premises	18
Part 4: Certificates of Compliance (fitness) for certain buildings.	19
19. Prohibition of public gatherings in certain circumstances	19
20. Application for certificate of fitness (compliance certificate).....	20
21. Requirements for certificate of fitness (compliance certificate).....	20
22. Form and content of certificate of fitness (compliance certificate)	20
23. Requirements of holder of certificate of fitness or compliance certificate	20

24. Cancellation of compliance certificate (fitness).....	21
Part 5: Water supply for fire-fighting purposes	21
25. Township development water supply requirements	21
26. Township development fire-extinguishing stream requirements	22
27. Fire risk category	22
Fire risk category	23
28. Fire risk categories	23
29. Connections to water reticulation system	24
Volume 3	24
CONTROL OF FIREWORKS.....	24
30. The use of fireworks is prohibited in the City of Mbombela area.....	24
31. Fireworks displays and the use of fireworks prohibited unless authorized.....	25
32. Application to present fireworks display and for the use of fireworks.....	26
33. Dealing in fireworks.....	26
Volume 4	27
CERTIFICATE OF REGISTRATION FOR USE, HANDLING AND STORAGE OF FLAMMABLE SUBSTANCES.....	27
35. Use, handling and storage of flammable substances prohibited in certain circumstances	27
36. Application for certificate of registration for flammable substances	27
37. Issue of certificate of registration	27
38. Availability of certificate of registration at premises	28
39. Fire-fighting equipment	28
40. Amendment to certificate of registration	29
41. Cancellation of certificate of registration.....	30
42. Renewal of certificate of registration	30
43. No authorization required for certain motor vehicle fuel tanks	30
44. Record of certificates of registration	30
Volume 5	30
46. Use, handling and storage of liquefied petroleum gas.....	31
47. Display of symbolic warning signs required.....	31
48. Duty to report fires, accidents and dumping	32
Volume 6	32
STORAGE OF FLAMMABLE SUBSTANCES	32
49. Storage of flammable substances prohibited in certain circumstances	32
50. Symbolic safety signs must be displayed – (screwed and photo illuminascent).....	32

51. Construction of flammable substance storerooms	32
52. Requirements for storeroom doors	32
53. Requirements for storeroom windows	33
54. Requirements for storeroom catch pits	33
55. Ventilation of storerooms	33
56. Electrical equipment in storerooms	34
57. Foam inlets required for certain storerooms	35
58. Shelving in storerooms	35
59. Unauthorized use and entry of storerooms prohibited	35
60. Mixing and decanting rooms	36
61. Temporary above ground storage of flammable substances	36
62. Hand tools must be intrinsically safe	36
63. Permanent above ground storage tanks for flammable liquids	36
64. Underground storage tanks for flammable liquids	37
65. Installing, erecting, removing and demolishing prohibited without prior notice	37
66. Repair and maintenance of access to storage tanks	37
67. Termination of storage and use of flammable substances	38
68. Container handling and storage	38
Volume 7	39
69. Transport of dangerous goods prohibited without permits	39
70. Application for transport permits	39
71. Requirements of transport permits	39
72. Cancellation of transport permit	40
73. Exemption from transport permits	40
74. Design, construction, maintenance and repair of road tankers	40
75. Design, construction, maintenance and repair of other vehicles	40
76. General prohibitions regarding transport of dangerous goods	41
77. Supply of dangerous goods prohibited in certain circumstances	41
78. Records of transport permits	42
Volume 8	42
SPRAY PAINTING	42
79. Spraying prohibited without spraying permit	42
80. Application for spraying permit	42
81. Cancellation of spraying permit	42
82. Duties of owner, occupier or person in charge of spraying room	42

83. Design and construction of spraying rooms	43
84. Water floors for spraying rooms	43
85. Electrical equipment in spraying rooms	43
86. Location of spraying rooms	44
87. Access to spraying rooms	44
88. Ventilation of spraying rooms.....	45
89. Fire dampers, protectors and alarms in spraying rooms	45
90. Design and positioning of ventilation outlets for spraying rooms.....	45
91. Display of signs on spraying rooms (screwed and photo illuminated).....	46
92. Manifold installations in spraying rooms.....	46
93. General prohibitions regarding spraying rooms.....	46
94. Fire extinguishing equipment in spraying rooms	46
Volume 9	47
FIRE BRIGADE SERVICES.....	47
95. Establishment and maintenance of Service	47
96. Objects of service	47
97. Services to other persons	47
98. Instructions by members of Service	48
99. Pretending to be member of Service prohibited	48
100. Certificates to identify members of Service	48
101. Cost of analysis samples	48
Volume 10	48
102. Event management	48
Volume11	53
MISCELLANEOUS.....	53
106. Handling animals during emergencies	53
107. Exemption from provisions of these by-law	53
108. Cancellation of approval, authorization or permission	54
109. By-laws bind State	54
110. Offences and penalties	54
111. Emergency exits and dangerous building /areas	55
113. Repeal of by-laws	55
114. Short title	55
SCHEDULE 1	55
GUIDELINE FOR EMERGENCY EVACUATION PLANS.....	55

SCHEDULE 2	57
EXEMPTION FROM CERTIFICATE OF REGISTRATION	57
SCHEDULE 3	58
EXEMPTION FROM TRANSPORT PERMIT	58
SCHEDULE 4	59
SANS CODES OF PRACTICE AND SPECIFICATIONS	59
SCHEDULE 5	60
REPEALED BY-LAWS	60
Number and Year	60
Name of By-laws	60
Extent of Repeal	60

Volume 1

APPLICATION AND INTERPRETATION OF BY-LAWS

1. Application of By-laws

1. (1). These by-laws apply -

- (a) within the area of jurisdiction of the Council; and
- (b) in addition to any applicable national or provincial law.

2. Definitions and Interpretation

2. (1) In these By-laws unless the context otherwise indicates -

“**above ground storage tank**” means a tank situated above ground for the storage of flammable substances as contemplated in SANS 0131 and SANS 089 Part 1 and SANS 087 Part 3;

“**agricultural holding**” means a portion of land not less than 0.8 hectares in extent used solely or mainly for the purpose of agriculture, horticulture or for breeding or keeping domesticated animals, poultry or bees;

“**approved**” means as approved by the Council;

“**bund wall**” means a containment wall surrounding an above ground storage tank, constructed of an impervious material and designed to contain 110% of the contents of the tank;

“**certificate of fitness**” means a certificate contemplated in section 20;

“**certificate of registration**” means a certificate contemplated in section 35;

“**Chief Fire Officer**” means the Chief Fire Officer appointed by the Council in terms of section 5 of the Fire Brigade Services Act and includes any person appointed as acting Chief Fire Officer;

“**Chief Inspector of Explosives**” means the Chief Inspector of Explosives appointed in terms of section 2 of the Explosives Act, 1956;

“**Civil Aviation Authority**” means the South African Civil Aviation Authority established in terms of section 2 of the South African Civil Aviation Authority Act, 1998 (Act No. 4 of 1998);

“**class**” means a class of petroleum product based on the following classification:

(a) **Class O**: liquefied petroleum gasses;

(b) **Class I**: liquids subdivided as follows:

(i) **Class IA**: liquids which have a closed-cap flash point below 23°C and a boiling point below 35°C; and

(ii) **Class IB**: liquids which have a closed-cap flash point below 23°C and a boiling point of 38°C or above;

(iii) **Class IC:** liquids which have a closed-cap flash point of 23°C or above but below 38°C;

(c) **Class II:** liquids which have a closed-cap flash point of 38°C or above but below 60,5°C;

(d) **Class IIIA:** liquids which have a closed-cap flash point of 60.5°C or above but below 93°C; and

(e) **Class IIIB:** liquids which have a closed-cap flash point of 93°C or above;

“Combustible liquid” means a liquid which has a close-cap flash point of 38°C or above;

“Competent person” means a person who is qualified by virtue of his or her experience and training;

“Compliance certificate” means fitness certificate or readiness in terms of fire safety requirements

“Council” means –

(a) the City Council of the Mbombela Municipality

(b) its successor in title; or

(c) a structure or person exercising a delegated power or carrying out an instruction, where any power in these By-laws, has been delegated or sub-delegated or an instruction given as contemplated in, section 59 of the Local Government: Municipal Systems Act, 2000 (Act No. 32 of 2000); or

(d) a service provider fulfilling a responsibility under these By-laws, assigned to it in terms of section 81(2) of the Local Government: Municipal Systems Act, 2000, or any other law,

as the case may be;

“dangerous goods” means any flammable gas, flammable liquid or flammable solid as contemplated in SANS 0228;

“dwelling house” means a single dwelling unit situated on its own site, including any motor vehicle garage and other domestic outbuildings on that site;

“dump” means to abandon or discard any hazardous substance by depositing, discharging, spilling or releasing it;

“emergency” means any incident or eventuality which seriously endangers or may endanger any person or property;

“emergency evacuation plan” means an emergency evacuation plan contemplated in section 17;

“emergency route” means that part of any escape route which-

(a) protects the occupiers of any building from fire; and

(b) leads to an escape door;

“enclosed place” in respect of domestic animals means any kraal, cage, camp or similar enclosure where domestic animals are kept or exercised ;

“escape door” means any door at the end of an emergency route and includes any door providing entrance to, or exit from, a building;

“**escape route**” means the entire path of travel, measured from an escape door to the furthest point in any room in a building;

“**explosives**” means explosives as defined in section 1 of the Explosives Act, 1956;

“**Explosives Act**” means the Explosives Act, 1956 (Act No. 26 of 1956), and any regulations made under that Act;

“**extinguishing stream**” means the amount of water that the Service needs in order to extinguish a fire;

“**feeder route**” means that part of an escape route which allows travel in two different directions to the access doors of at least two emergency routes;

“**Fire Brigade Services Act**” means the Fire Brigade Services Act, 1987 (Act No. 99 of 1987), and any regulations made under that Act;

“**fire damper**” means an automatic damper, including its assembly, which complies with the requirements of SANS 193;

“**fire-fighting equipment**” means any portable or mobile fire extinguisher, hose reel or fire hydrant;

“**fire installation**” means any water installation which conveys water solely for the purposes of fire-fighting;

“**fireworks**” means any explosive device or substance which burns or explodes after ignition, including firecrackers, and which is regulated under the Explosives Act;

“**fireworks display**” means the use of fireworks for purposes of a public display;

“**flammable gas**” means a gas which at 20oC and a standard pressure of 101,3 kilopascals –

(a) is ignitable when in a mixture of 13% or less (by volume) with air; or

(b) has a flammable range with air of at least 12%, regardless of the lower flammable limit;

“**flammable liquid**” means a liquid or combustible liquid which has a closed-cap flash point of 93oC or below;

“**flammable substance**” means any flammable liquid, combustible liquid or flammable gas;

“**Group I, II, III, V, VI, VIII and IX hazardous substances**” means Group I, II, III, V, VI, VIII and IX hazardous substances, as the case may be, as contemplated in the Hazardous Substances Act;

“**hazardous substance**” means any hazardous substance contemplated in the Hazardous Substances Act;

“**Hazardous Substances Act**” means the Hazardous Substances Act, 1973 (Act No. 15 of 1973), and any regulations made under that Act;

“**liquefied petroleum gas**” means a mixture of light hydrocarbons (predominantly propane and butane) that is gaseous under conditions of ambient temperature and pressure and that is maintained in a liquid state by an increase of pressure or lowering of temperature;

“**member**” means a member of the Service and includes the Chief Fire Officer;

“**National Building Regulations and Building Standards Act**” means the National Building Regulations and Building Standards Act, 1977 (Act No. 103 of 1977), and any regulations made under that Act;

“**National Road Traffic Act**” means the National Road Traffic Act, 1996 (Act No. 93 of 1996), and any regulations made under that Act;

“**Occupational Health and Safety Act**” means the Occupational Health and Safety Act, 1993 (Act No 85 of 1993);

“**occupier**” means any person who occupies or has control over any premises;

“**owner**” in relation to premises, means the registered owner of the premises and includes -

(a) any person who receives rental or profit from the premises, whether on own account or as agent;

(b) a body corporate in respect of any sectional title scheme contemplated under the Sectional Titles Act, 1986 (Act No. 95 of 1986); and

(c) an executor or curator of any deceased or insolvent estate;

“**premises**” means any land, building, construction or structure or part thereof and includes any train, boat, aircraft or other vehicle;

“**prescribed fee**” means a fee determined by the Council by resolution in terms of section 10G(7)(a)(ii) of the Local Government Transition Act, 1993 (Act No. 209 of 1993), or any other applicable legislation;

“**public gathering**” includes any gathering by members of the public-

(a) to view any theatrical or operatic performances, orchestral or choral recitals or cinematic-graphic screenings; or

(b) to attend, practice or participate in any indoor sports activity, dance, physical activity or other recreational activity;

“**public place**” means any path, street, walk-way, side-walk, park, place of rest or other place to which the public has authorized or unimpeded access;

“**pyro technician**” means any appropriately qualified person responsible for the use of fireworks at a fireworks display;

“**registered premises**” means any premises in respect of which a certificate of registration has been issued;

“**SANS**” means the South African National of Standards contemplated in section 2 of the Standards Act, No. 29 of 1993, and SANS followed by any number means a reference to a SANS code of practice, specification or standard of the corresponding number;

“**Service**” means the Fire Brigade Service established and maintained by the Council as contemplated in section 95;

“**service installation**” means any automatic fire-extinguishing installation, fire pump connector, fire pump, emergency power or stand-by generator, fire detection, locating or alarm system, emergency lighting or evacuation communication system, mechanical ventilation system, pressure regulation system, smoke ventilation system, hoist, symbolic safety sign and smoke or fire door assembly;

“**spray**” means to spray, coat, plate or epoxy-coat with any hazardous substance and “spraying” has a corresponding meaning;

“**spraying permit**” means a permit contemplated in section 79;

“**spraying room**” means a room contemplated in section 83;

“**storage vessel**” means a pressure vessel as defined in the Regulations for Pressure Vessels made under the Occupational Health and Safety Act;

“**store room**” means a room for storage of flammable substances contemplated in section 49;

“**underground tank**” means any tank used or intended to be used for the storage of any flammable liquid and which is wholly sunk into and below the surface of the ground;

“**use**” in relation to fireworks means discharging, lighting or igniting;

“**vegetation**” includes grass, weeds, leaves, shrubs and trees; and

“**vehicle**” includes a trailer or semi-trailer which-

(a) has at least 4 wheels with independent axles and suspension systems; and

(b) can be hitched to a truck-tractor or any other motor vehicle contemplated in the National Road Traffic Act.

“**water installation**” means a water installation as defined in the Council’s Water Services By-laws.

(2) If any provision in these by-laws vests or imposes any power, function or duty of the Council in or on an employee of the Council and such power, function or duty has in terms of section 81(2) of the Local Government: Municipal Systems Act, 2000 or any other law been assigned to a service provider, the reference in such provision to such employee must be read as a reference to the service provider or, where applicable, an employee of the service provider authorized by it.

Volume 2

FIRE PREVENTION AND FIRE PROTECTION

Part 1: Fire Prevention

No fires are allowed to be made in the area of the City of Mbombela as it is deemed to be a smokeless area.

3. Certain fires prohibited

(1) No person may make or allow any other person to make a fire that may endanger any person, animal or property.

(2) No person may burn or allow any other person to burn any refuse or combustible material—

- (a) without the prior written permission of the Chief Fire Officer; or
 - (b) unless the refuse or combustible material is burnt in an approved incinerating device.
- (3) Any person who makes a fire or allows any other person to make a fire, must take reasonable steps and have the minimum firefighting equipment available to ensure that the fire and the effects of fire does not infringe upon the rights (discomfort) of any person or endanger any person, animal or property.
- (4) No person is allowed to burn any rubbish, leaves or any burning material in residential or business areas.
- (5) The prohibition in subsection (2) does not apply to any fire made–
- (a) in an approved and purpose-made stove, fireplace or hearth that forms an integrated part of a building or structure;
 - (b) for the purpose of preparing food on private premises set aside for that purpose; or
 - (c) in any device for preparing food which –
 - (i) is heated by electricity or liquefied petroleum gas; and
 - (ii) is so positioned that the fire does not endanger any person, animal or property.
 - (d) for the purpose of providing heat to a person during winter provided that the fire is made in a safe area.
- (6) Any person who fails to comply with the provisions of this section will be guilty of an offence.

4. 1. Storage and accumulation of combustible material prohibited

- (1) No person may store any combustible material or allow it to be stored, at any place or in any manner that may pose a fire hazard to any person, animal or property.
- (2) No person may allow the accumulation of saw dust at any place in quantities sufficient to pose a fire hazard to any person, animal or property.
- (3) No person may use or allow to be used any sawdust or similar combustible material to soak up any flammable liquid.
- (4) No person may allow soot or any other combustible material to accumulate in any chimney, flue or duct in such quantities or in any manner that may pose a fire hazard to any person or property.
- (5) No person may allow any vegetation to become overgrown at any place under that person's control that may pose a fire hazard to any person, animal or property.

4.2. Housekeeping

- (1) any occupier, owner must ensure that their properties are clear from any material which may cause fire hazard but if the situation arises the owner or occupier of the property concerned must without delay eliminate the hazard or cause the hazard to be eliminated by -

- (a) cutting any grass, leaves or weeds associated with the fire hazard to a maximum height of 150 millimeters;
- (b) pruning, chopping down or sawing any shrub or tree which may danger the property; and
- (c) removing any resulting combustible,
- (d) old tyres, plastics residue from the property.

5. Electrical fittings, equipment and appliances

No person may cause or allow –

- (a) any electrical supply outlet to be overloaded; or
- (b) any electrical appliance or extension lead to be used in any manner that may pose a fire hazard to any person or property.

6.1. Flame-emitting devices

No person may use or cause or allow the use of any flame-emitting device, including but not limited to any candle, lantern or torch, in any manner that may pose a fire hazard to any person or property.

6.2. Veld and Forestry

Fire breaks specifications and the deliberate making of fire and permission granted to be under the provisions and prohibitions of the City of Mbombela or LEFPA and the National Veld and Forrest Act as described under Veld and Forestry.

The City of Mbombela operates under the National Veld and Forest Act. 101 of 1998.

1. Stipulations:

a) That no person within the boundaries of the City of Mbombela shall make a fire, or allow a fire to continue to burn or add fuel to a fire from the 1st of June to the 31st of October yearly unless a burning permit is obtained from LEFPA, taking in account the Average Fire Danger Index for the specific day etc.

The Chief Fire Officer, may however intervene if deemed necessary to halt all operations regarding such an arrangement given specific circumstances, or may overrule such an arrangement under the provisions of the Fire Services Act..

b) That Fines and Penalties be issued in accordance with Section 57(5a) of the Criminal Procedure Act 51 of 1977 and National Veld and Forest Fire Act 101 of 1998 Article 25(1) to and including Article 25(6) (b)

c) That any land owner, occupier or person that lives or visits within the City of Mbombela boundaries, be subjected to the provisions and the prohibitions as stipulated by LEFPA and subsequently, the National Veld and Forrest Act. 101 of 1998.

7. Safety fire-breaks required

Burning fire –breaks during the fire season from the 1st of June – 31st of October, is subjected to approval from LEFPA and the Chief Fire Officer of the City of Mbombela as described under Veld and Forestry Stipulations (1).

(1) Every owner or occupier of an agricultural holding or farm must clear and maintain a safety fire-break along every boundary of the agricultural holding or farm that–

(a) is at least 5 meters wide (when measured parallel from the boundary concerned); and

(b) contains no vegetation or combustible residue.

(2) If an obstruction occurs within the boundaries of a safety fire-break, the owner or occupier concerned must clear and maintain a 5 meter-wide safety fire-break around that obstruction.

(3) No person may clear or maintain a safety fire-break by burning without the prior written permission of the Chief Fire Officer.

(4) Any person who intends to clear or maintain a safety fire-break by burning must–

(a) apply in writing to the Chief Fire Officer for permission, stipulating the property concerned and the proposed date and time of the burning; and

(b) unless the burning is to be performed by a person or body accredited for this purpose by the Council, request the Service to provide assistance at the burning against payment of the prescribed fee.

(5) Any person who fails to comply with the provisions of this section will be guilty of an offence.

Part 2: Fire Protection

8. Design and construction of buildings

(1) Subject to the provisions of subsection (3), every owner of a building, excluding a dwelling house, must ensure that it is designed and constructed in a manner that -

(a) provides for –

(i) the effective drainage of any water that may result from fire-extinguishing activities; and

(ii) the discharge of that water directly into a storm water drain;

(b) prevents any water that may result from fire-extinguishing activities from draining–

(i) down any stairway or lift shaft;

(ii) down any electrical shaft or telecommunications service shaft;

(iii) down any shaft that is connected to a basement level; or

(iv) along any approach to a building or any vehicle access ramp leading to or from a building;

(c) if any water resulting from fire-extinguishing activities should spill into a basement, that water is discharged directly into a storm water drain; and

(d) complies with the requirements of SANS 0400 (Parts A, K, M, O, T, V and W) insofar as it relates to fire protection.

(2) Subject to the provisions of subsection (3), every owner of a building equipped with a transformer room must ensure that—

(a) the transformer room is situated on the ground level;

(b) access to the transformer room is from outside the building; and

(c) there is adequate and ready access to the transformer room for fire-fighting and maintenance activities.

(3) Subsections (1) and (2) do not apply in respect of any building which exists at the commencement of these By-laws.

(4) Any building design for offices, businesses, church, halls, gymnasium, guest house etc. must be submitted to the fire, engineer or fire consultant in terms of SANS 10400 Part T.

(5) Timber house plan must be submitted with rational design certificate developed by the competent person (Fire engineer, Fire Consultant accredited)

9. Design and construction of dumping sites

(1) Every person who designs or constructs any dumping site, must ensure that it is designed and constructed in accordance with the instructions of—

(a) the Department of Water Affairs and Forestry; and

(b) the Council.

(c) the dumping site must also adhere to 7 safety fire breaks required (1)(a)(b) for dumping sites on agricultural holdings or farms

10. Design and construction of other structures and sites

(1) Every person who designs, constructs or erects any of the following structures, must ensure that they comply with a rational design as contemplated by the National Building Regulations and Building Standards Act -

(a) any grain silo;

(b) any atrium;

(c) any air traffic control tower;

(d) any tower for telecommunications or other uses;

(e) any thatched structure which is larger than 20 square meters and situated within 4.5 meters of any boundary line of the property concerned;

- (f) any tent or other temporary structure for holding a public gathering; and
 - (g) any open-plan commercial or industrial premises with a covering distance that exceeds 45 meters measured from any point in the premises to any escape or exit door.
- (2) Every person who designs or constructs any aircraft hanger or helicopter pad, must ensure that it–
- (a) complies with a rational design as contemplated by the National Building Regulations and Building Standards Act;
 - (b) provides for the effective drainage of any liquid from the floor of the hanger or helicopter pad or any approach to the aircraft hanger or helicopter pad;
 - (c) provides for the effective channeling of any liquid from the floor of the hanger or helicopter pad to a drainage area connected to a separator well;
 - (d) prevents the spread of any liquid from the floor of the hanger or helicopter pad; and
 - (e) is equipped with effective earthing devices for the discharge of static electricity.

11. Requirements for sprinkler systems

- (1) If a sprinkler system is required in any building in accordance with SANS 0400, SANS 087 (Part III) or SANS 089 (Part I) or if the Council so requires, the owner of the building must ensure that the building is equipped with a sprinkler system.
- (2) Every person who designs, constructs or installs a sprinkler system must ensure that it is designed, constructed and installed -
- (a) in accordance with SANS 0287; and
 - (b) in compliance with the requirements of SANS 0400 (Parts A, K, M, O, T, V and W) insofar as it relates to fire protection.

12. Requirements for extractor fan systems

- (1) Every person who designs, constructs or installs an extractor fan system, any related ducts or any similar chimney system and every owner of a building in which such a system is installed must ensure that–
- (a) it is designed, constructed and installed in a manner that provides for clearly demarcated, adequate and easy access for inspection, maintenance and repairs; and
 - (b) the conduit and outlet of any such system is installed in a manner that does not result in a fire hazard to any person or property.
- (2) Every owner of a building in which an extractor fan system, any related ducts or any similar chimney system has been installed, must ensure that every filter, damper, screen or conduit forming an integral part of the system is regularly inspected, cleaned and maintained to ensure that fatty residues or any other combustible residues do not accumulate.

13. Requirements for emergency exits

(1) Every owner of a building must ensure that any escape door in that building—

- (a) is fitted with hinges that open in the direction of escape; and
- (b) is equipped with a fail-safe locking device or devices that do not require a key in order to exit.

(2) Every owner of a building must ensure that any door in a feeder route—

- (a) is a double swing-type door;
- (b) is not equipped with any locking mechanism.

(3) Notwithstanding the provisions of subsection (2), if it is necessary that a door, in a feeder route be locked for security reasons, the owner of the building must provide an alternative means of escape approved by the Chief Fire Officer.

(4) No person may obstruct or allow the obstruction of any escape route from any premises that may prevent or hinder the escape of any person or animal from the premises in an emergency.

14. Design, identification and access for fire-fighting and rescue purposes

14. (1) Subject to the requirements of any town planning scheme or the conditions of establishment of any township, every person who plans, designs or constructs a building, excluding a dwelling house, must ensure that the premises on which the building is situated, is or are planned, designed and constructed so that—

- (a) at least one elevation of the building fronts onto a street;
- (b) if the premises do not front onto a street, an access road is provided with dimensions and carrying capacity approved in writing by the Chief Fire Officer;
- (c) there is a climate-proof and weather-proof parking surface for parking and operating fire brigade machines and equipment in an emergency -
 - (i) of dimensions at least 10 meters wide;
 - (ii) that runs the full length of the side elevation of the building that borders the surface; and
 - (iii) with a carrying capacity of at least 70 metric tons; and
- (d) any entrance arch to the premises provides an opening with dimensions at least 4 meters wide x 4.2 meters high, unless there is an alternative and easy access route to the premises of at least the same dimensions.
- (e) In order to gain rapid access to an area or building, the width dimension could increase to 5.5 meters if the access to the premises happens to be on a sharp corner, or subjected to other interfering obstacles.
- (f) In other challenging circumstances, the Chief Fire Officer may make a ruling or regulation in terms of access to ensure a rapid and safe emergency response to the premises.

(2) For purposes of easy identification by any member of the Service in an emergency, every owner or occupier of premises must ensure that the correct street number of the premises—

(a) is displayed clearly on the street boundary of the premises in numbers at least 75 millimeters high; and

(b) is visible from the street; and

(c) is maintained in a legible condition at all times.

15. Barricading of vacant buildings

(1) Every owner or person in charge of a building or portion of a building that is vacant must, at his or her own cost and to the satisfaction of the Chief Fire Officer –

(a) remove all combustible waste and refuse from the building; and

(b) block, barricade or otherwise secure all windows, doors and other openings in the building in a manner that will prevent the creation of any fire hazard caused by entering of the building by any unauthorized person.

15.2. Building Plans

(a) All fire plans (except H4 - Dwelling house) must be done by a competent fire consultant or fire engineer.

Part 3: Fire Fighting Equipment and Emergency Evacuation Plans

16. Installation and maintenance of fire-fighting equipment

(1) Every owner of a building must ensure that—

(a) all fire-fighting equipment and service installations on the premises are installed in a manner and condition ready for use in an emergency;

(b) all portable and mobile fire-extinguishers and all hose reels on the premises are serviced and maintained in accordance with SANS 0105 and SANS 1475;

(c) all fire-fighting equipment and service installations on the premises are -

(i) maintained in a good working condition by a competent person;

(ii) inspected and serviced in accordance with manufacturer specifications; and

(iii) are inspected by an appropriately registered and competent person at least once every 12 months; and

(d) a comprehensive service record of all fire-fighting equipment and service installations on the premises is maintained and furnished to the Chief Fire Officer every 12 months.

(2) Every person who inspects, services or repairs any fire-fighting equipment or service installation must—

(a) on completing the inspection, service or repairs, as the case may be –

(i) certify in writing that the equipment or installation concerned is fully functional; and

- (ii) furnish that certificate to the owner of the premises; or
- (b) if the equipment or installation cannot readily be repaired to a functional state, notify the Chief Fire Officer of this fact in writing without delay.
- (3) Except for purposes of inspection, service, repair or fire-fighting, no person may remove or interfere with any fire-fighting equipment or service installation at any premises.
- (4) No person may alter, damage, misuse or render ineffective any fire-fighting equipment or service installation at any premises.

17. Chief Fire Officer may designate premises for emergency evacuation plans

- (1) The Chief Fire Officer may by written notice designate any premises or premises where an event could be held, as a premises requiring an emergency evacuation plan.
- (2) The notice contemplated in subsection (1), must be served on the premises concerned and addressed to the owner or occupier.

18. Duties of owner or occupier of designated premises

(1) The owner, or with the approval of the Chief Fire Officer, the occupier, of any premises designated in terms of section 17 must –

- (a) prepare a comprehensive emergency evacuation plan for the premises in accordance with the guideline contained in **Schedule 1** and submit it to the Chief Fire Officer in triplicate within 30 days of service of the designation notice;
 - (b) establish a fire protection committee comprised of occupiers of the premises to assist the owner or occupier to organize a fire protection program and regular and scheduled fire evacuation drills;
 - (c) ensure that the emergency evacuation plan is reviewed-
 - (i) at least every 12 months;
 - (ii) whenever the floor layout of the premises is changed; and
 - (iii) whenever the Chief Fire Officer requires revision of the plan;
 - (d) ensure that an up-to-date emergency evacuation plan, any fire protection programs, evacuation drills and any related documents are kept, maintained and all times available in a control room on the premises for inspection by any member of the Service; and
 - (e) identify a place of safety (Assembly area) off the designated premises, but in the immediate vicinity of the premises, where persons who reside or work on the premises may gather during an emergency for the purpose of compiling a list of survivors.
- (2) The owner or occupier of a building or premises, with special reference to the Occupational Health and Safety Act. No: 85 of 1993, must comply with regards to:
- (a) the appointment of Safety Representatives as per requirement

(b) To ensure that relevant structures are in place to deal with emergencies, and to ensure the health and safety of occupants in the building or premises, including an overall emergency plan that will include an evacuation plan with emergency routes and assembly points, etc.

(c) the appointment of other deemed to be necessary personnel as per the Occupational Health and Safety Act. with reference to Fire or Floor Marshals, Fire Fighters, First Aiders, Assembly Point Managers, etc.

(d) Training for the appointed staff members in terms of the OHS Act. meaning Safety Representatives, Fire or Floor Marshals, Fire Fighters, First Aiders, etc., to be conducted by a SAQA accredited and certified service provider.

(e) insuring the functionality, regular checking and maintenance of water supplies to and in the premises, fire-fighting equipment, signage, etc.

(f) The owner or occupier of a building or premises to comply in terms of the requirements of the Occupational Health and Safety Act., as directed by the Labor Act., and ensure that emergency exercises

or evacuation drills be conducted preferably quarterly, but at least twice a year. The owner or occupier may make a request to the Chief Fire Officer to have members of the Fire and Rescue Services to take part or oversee the exercise or drill and make comments.

(g) The Chief Fire Officer will subsequently decide if there will be charges of service fees payable by such owner or occupier for services rendered and how much it will be.

(3) The Chief Fire Officer may in respect of premises designated in terms of section 17 -

(a) require the review of any emergency evacuation plan by the owner or occupier and may provide directions in this regard;

(b) instruct the owner or occupier to implement a fire protection program that the Chief Fire Officer believes is necessary to ensure the safety of persons and property on the premises; and

(c) require the owner or occupier or event organizer, to provide the Chief Fire Officer with a certified copy of the emergency evacuation plan and any associated documents at a specified time and place.

Part 4: Certificates of Compliance (fitness) for certain buildings.

19. Prohibition of public gatherings in certain circumstances

(1) No person may hold a public gathering or allow a public gathering to be held in any building or temporary structure unless a Compliance certificate (fitness) has been issued by the Chief Fire Officer in respect of that building or temporary structure, unless a certificate of fitness previously issued in terms of this subsection, has not yet expired.

(2) Subsection (1) does not apply in respect of a building or temporary structure which existed at the commencement of these By-laws, unless after that date –

(a) the building or temporary structure is rebuilt, altered, extended or its floor layout is changed; or

(b) ownership or control of the building or structure changes.

20. Application for certificate of fitness (compliance certificate)

(1) Every owner of a building or temporary structure intended for the holding of a public gathering must -

(a) complete and submit to the Chief Fire Officer an application form for a certificate of fitness in the form and manner determined by the Council; and

(b) pay the prescribed fee.

(2) An application contemplated in subsection (1) must be submitted at least 30 days before any intended public gathering.

(3) The Chief fire officer may close any building with immediate effect if he deem that it may pose danger to any occupancy of that building

21. Requirements for certificate of fitness (compliance certificate)

21(1) The Chief Fire Officer may not issue a certificate of fitness in respect of a building or temporary structure -

(a) unless the Council is in possession of an up-to-date set of building plans for the premises;

(b) unless the building or temporary structure complies with the requirements of these By-laws; and

(c) for a period of validity exceeding 12 months.

22. Form and content of certificate of fitness (compliance certificate)

22(1) A certificate of fitness must be in the form determined by the Council and must at least record the following information, where applicable:

(a) The trade name and street address of each occupier of the building or temporary structure;

(b) a description of the type of activity carried on by each occupier of the building or structure;

(c) the full names and addresses of the persons who serve on the governing or similar body of each occupier;

(d) the maximum permissible number of people who may be admitted to the useable floor area of the building or structure;

(e) the number of emergency exits and their dimensions; and

(f) the dates of issue and expiry of the certificate and its reference number.

23. Requirements of holder of certificate of fitness or compliance certificate

(1) The holder of a certificate of fitness or compliance certificate must -

(a) comply with the provisions of the certificate of compliance (fitness);

(b) at all times –

(i) display the certificate prominently on the premises; and

(ii) maintain the certificate in a legible condition;

(c) immediately notify the Chief Fire Officer in writing of any change to the trade name, activity or governing or similar body of any occupier of the building or structure; and

(d) submit any application for renewal of the compliance certificate (fitness) at least 30 days before its expiry in the form and manner determined by the Council together with the prescribed fee.

24. Cancellation of compliance certificate (fitness)

(1) The Chief Fire Officer may cancel any certificate of compliance in respect of a building or temporary structure if he or she has reason to believe that -

(a) the owner or occupier concerned contravenes or fails to comply with any provision of these By-laws; or

(b) the building or structure contravenes or does not comply with the requirements of these By-laws.

(2) Subject to subsection (3), before the Chief Fire Officer cancels a certificate of fitness as contemplated in subsection (1), he or she must -

(a) give the owner or occupier concerned written notice of the intention to cancel the certificate of fitness and the reasons for such cancellation;

(b) give the owner or occupier concerned a period of at least 20 days to make written representations regarding the matter; and

(c) consider any representations received.

(3) If the Chief Fire Officer has reason to believe that the failure to cancel a compliance certificate within the period contemplated in subsection (2)(b), may endanger any person or property, he or she may cancel a certificate of fitness without prior notice to the owner or occupier concerned.

(4) If the Chief Fire Officer cancels a compliance certificate in terms of subsection (3), he or she must -

(a) furnish the owner or occupier of the building or temporary structure concerned with written notice of the cancellation;

(b) provide the owner or occupier a period of at least 20 days to make written representations regarding the cancellation; and

(c) consider any representations received.

(5) The Chief Fire Officer may, after considering the representations contemplated in subsection (4), reverse the decision to cancel the compliance certificate

Part 5: Water supply for fire-fighting purposes

25. Township development water supply requirements

(1) Every person who develops or redevelops a township must design and develop that township with a sufficient water supply for purposes of fire-fighting by members of the Service.

(2) Every person who develops or redevelops a township must ensure that -

(a) the storage capacity and rate of replenishment of the reservoirs supplying water to the township are sufficient for the fire-fighting purposes contemplated in these By-laws;

(b) the water supply from these reservoirs is reticulated in a manner that ensures that the water supply to any area in the township can be provided from at least two directions; and

(c) double supply mains are installed from the water supply source to the distribution reservoirs and double pumps are installed for the delivery of the water supply.

(3) Subsection (2) (c) is deemed to be satisfied, if -

(a) the water is supplied to the township from more than one reservoir;

(b) each reservoir receives water from a separate supply main and pump; and

(c) the reservoirs are connected to each other.

(4) Every person who develops or redevelops a township must ensure that -

(a) the water distribution system is designed and equipped with control valves positioned so that it is not necessary to close off any branch or any portion of the distribution system for more than 150 meters in any high risk area or for more than 300 meters in any moderate or low risk area in the event that the system, excluding any of the branches, is damaged or requires repair; and

(b) if the redevelopment of any township alters the fire risk category of any area in the township as contemplated in section 28, the water reticulation system is adapted without delay so as to comply with the requirements of sections 26 and 27.

(c) No one is allowed to use Fire extinguisher for personal purposes other than firefighting failure to comply will lead to punishable offence as schedule in section 107(2)

(5) every owner or occupier of an agricultural holding or farm or house must have reasonable firefighting equipment to combat the spread of an fire from the property.

(d) Subsection 5 will be determine by the Chief Fire officer after assessment of the property

26. Township development fire-extinguishing stream requirements

(1) Every person who develops or redevelops a township must ensure that the water supply provides a fire-extinguishing stream that is immediately available to members of the Service in an emergency, of the following volume and duration:

27. Fire risk category

Township development fire hydrant requirements

Fire risk category	Minimum volume of extinguishing stream (liters per minute)	Minimum duration of extinguishing stream (hours)
High risk	11 500	6
Moderate risk	5 750	4

Low risk	2 300	2
-----------------	--------------	----------

(1) Every person who develops or redevelops a township must ensure that fire hydrants are plotted on a plan and installed in accordance with the following minimum delivery volumes and distance frequencies:

Fire risk category

Minimum fire hydrant delivery volume measured at peak consumption (liters per minute)

Minimum distance between fire hydrants (meters)

Fire risk category	Minimum fire hydrant delivery volume measured at peak consumption (liters per minute)	Minimum distance between fire hydrants (meters)
High risk	1980	120
Moderate risk	1 150	180
Low risk	900	240

(2) Every person who develops or redevelops a township must ensure that the position of fire hydrants are plotted accurately on a plan that is furnished to the Chief Fire Officer for operational fire-fighting purposes.

28. Fire risk categories

(1) For purposes of sections 26 and 27, the following areas of a township must be regarded –

(a) as high risk –

- (i) any factory area, high density shopping area, warehouse or commercial building;
- (ii) any plantation, timber yard or wooden building;
- (iii) any building higher than 3 stories;
- (iv) any building in which hazardous substances are used, handled or stored or in which hazardous processes are conducted; and
- (v) any other area that has a high fire risk or high fire spread risk;

(b) as moderate risk -

(i) any area in which –

- (aa) factories, commercial buildings or residential buildings are generally detached from each other and do not exceed 3 stories; and

(bb) the Chief Fire Officer has not declared the materials processed or stored in these buildings as highly dangerous;

(ii) any area where the fire risk and spread risk of fire is moderate; and

(iii) any other area that is not a high or low risk area; and

(c) as low risk –

(i) any area that is mainly residential or semi-rural;

(ii) any area that has predominantly detached, duet, cluster or town house developments; and

(iii) any area where the fire risk or risk of spread of fire is slight or insignificant.

29. Connections to water reticulation system

(1) No person may obtain a water connection to the water reticulation system of the Council unless the fire protection plans for the premises to be connected have been approved by the Chief Fire Officer.

(2) Every person or owner of premises who requires a water connection to the water reticulation system of the Council must -

(a) if the premises to be connected are protected by a sprinkler installation, ensure that –

(i) the connection is calculated and designed for each sprinkler installation in accordance with a rational design as contemplated in the National Building Regulations and Building Standards Act, and

(ii) the size, delivery pressure and flow of the water connection is calculated in advance by the responsible engineer;

(b) if the Chief Fire Officer requires a larger water connection for purposes of fire-fighting, provide the larger water connection;

(c) ensure that the size, work pressure and delivery flow, except in the case of a water connection to a sprinkler installation, is calculated and designed in accordance with SANS 0400 (Part W); and

(d) ensure that the water installation upon completion complies with the provisions of SANS-1:1994.

Volume 3

CONTROL OF FIREWORKS

Use of fireworks are prohibited within the boundaries of the City of Mbombela with special reference to the Explosives Act 26 of 1956, the Explosives Act 15 of 2003 and the Animal Protection Act 71 of 1962.

30. The use of fireworks is prohibited in the City of Mbombela area.

(1) Unless so authorized in terms of section 33, no person may use fireworks –

(a) within 1 000 meters of an airport; explosives facility, fuel depot, liquefied petroleum Gas Depot, gasometer, hospital, old age home or home caring for the old and frail;

(b) inside any building;

(c) within 500 meters from any industrial premises, SPCA, nature reserve, kennels, stables, zoo or on any agricultural holding;

(d) at any public place; or event;

(e) at any school;

(f) within 500 meters of a South African Police Service Centre

(2) No person may light or ignite fireworks in any place where other humans or animals are at risk.

(3) (1) Unless so authorized in terms of section 32, no person may light or ignite fireworks on any day or at any time except -

(a) New Year's Eve from 18h00 to 01h00;

(c) Hindu festival (Diwali) from 18h00 to 24h30;

(d) Chinese New Year from 18h00 to 24h30;

(e) Guy Fawkes day from 18:00 to 24h30

(3)(ii) Any day applied for and approved by the Chief Fire Officer

(4) No person may allow any minor under his or her control to use, light or ignite fireworks in contravention of subsection (1), (2) or (3).

(5) Use of Chinese lanterns are strictly prohibited in the City of Mbombela

31. Fireworks displays and the use of fireworks prohibited unless authorized.

(1). No person may present a fireworks display unless -

(a) authorized to do so by the Chief Fire Officer as appointed by Council as contemplated in section 33;

The Chief Fire Officer will decide by using his/her discretion, whether to deploy the Fire and Rescue Services to the area, or not, and if there will be a Service Fee, or not, depending on the situation, risk profile, etc.

(b) authorized to do so by the ATNS; and the Chief Inspector of Explosives;

(c) the display is at all times under that person's supervision and control;

(d) that person has ensured that -

(i) an area with a radius of at least 50 meters is clearly demarcated for the launching of fireworks at the display; and

(ii) a safe fall down area for fireworks debris be established.

(iv) measures are in place to prevent any person who is not involved in the presentation of the display from entering this launching area; and

(e) a pyro technician or fireworks technician is at all times present and responsible for the use of fireworks at the display.

32. Application to present fireworks display and for the use of fireworks.

(1) Any person who wishes to present a fireworks display or use fireworks must apply to the Chief Fire Officer for approval by completing and submitting an official Council Fireworks Application Form in the form and manner determined by the Council together with the prescribed fee and the following documentation:

(a) Proof of permission for the fireworks display from the ATNS if the fireworks are to take place within 1 000 meters of an airport.

(b) proof that an application for the fireworks display has been submitted to the Chief Inspector of Explosives at the South African Police Service (SAPS);

(c) a sketch plan of the proposed venue for the fireworks display, including the demarcated area for the launching of the fireworks as provided on the Council Fireworks Application Form.

d) That all relevant sections of the Fireworks Application Form be completed including all relevant signatures.

e) Any person who fails to comply with the provisions of this section will be guilty of an offence.

(2) The application, prescribed fee and accompanying documentation must be submitted to the Chief Fire Officer for processing at least 14 days before the date of the proposed fireworks display.

The Chief Fire Officer will then arrange for an inspection by the Fire and Rescue Services to the proposed area prior to the event taking place.

(3) As per Council Fireworks Application Format, the organizer of such event will be held responsible in terms of doing the necessary public awareness regarding fireworks and dealing with/notifying the local SPCA.

(4) The Chief Fire Officer may, depending on circumstances, and changing risk factors, disapprove any

previously approved fireworks application.

33. Dealing in fireworks

(1) No person may deal in fireworks unless -

(a) that person holds the required fireworks license in terms of the Explosives Act; and

(b) has the written authority of the Chief Fire Officer.

(2) Any person who wishes to obtain the written authority of the Chief Fire Officer to deal in fireworks as contemplated in subsection (1)(b), must -

(a) complete an application in the form and manner determined by the Council; and

(b) submit it to the Chief Fire Officer together with the prescribed fee at least 30 days before the authority is required by the applicant.

(3) The Chief Fire Officer may cancel any written authority to deal in fireworks if the holder of the authority contravenes or fails to comply with any provision of these By-laws or any other applicable law.

(4) Displaying of fireworks are allowed in dedicated areas as per council notices prior to event.

Volume 4

CERTIFICATE OF REGISTRATION FOR USE, HANDLING AND STORAGE OF FLAMMABLE SUBSTANCES

35. Use, handling and storage of flammable substances prohibited in certain circumstances

(1) Subject to the provisions of subsection (3), no person may use, handle or store any flammable substance or allow such substance to be used, handled or stored on any premises unless that person is the holder of a certificate of registration issued by the Chief Fire Officer in respect of the flammable substance and the premises concerned.

(2) A certificate of registration contemplated in subsection (1) is not required if the flammable substance concerned is of any class and does not exceed the quantity stipulated in **Schedule 2**.

(3) No person may use, handle or store any flammable substance in respect of which no certificate of registration is required or allow such substance to be used, handled or stored on any premises, unless the flammable substance -

(a) is used, handled or stored in a manner that ensures that –

(i) no flammable substance nor any flammable substance fumes come into contact with any source of ignition that may cause the flammable substance or fumes to ignite;

(ii) in the event of a fire or other emergency, the escape of any person or animal is not hindered or obstructed in any way; or

(b) is used, handled or stored -

(i) in a naturally ventilated room that prevents the accumulation of fumes or gas;

(ii) in a suitable place outdoors that ensures the safe disposal of fumes or gas; or

(c) the flammable substance is stored in strong, gas-tight and labelled containers.

36. Application for certificate of registration for flammable substances

An application for a certificate of registration contemplated in section 35(1) must be completed and submitted in the form and manner determined by the Council and certificate will be for a period 12 months from date of issue, together with the prescribed fee.

37. Issue of certificate of registration

(1) If the Chief Fire Officer issues a certificate of registration to any person, that Officer must endorse on the certificate -

- (a) the class and quantity of the flammable substance for which the premises have been registered;
 - (b) the number of storage tanks or storage facilities on the premises and their capacities;
 - (c) the number of flammable substance storerooms on the premises and their capacities;
 - (d) the number of liquefied petroleum gas installations, types of installations and the combined capacity of all cylinders that may be stored on the premises;
 - (e) the number of storage facilities for any other flammable substance and the volume of each such facility;
 - (f) the period of validity and expiry date of the certificate; and
 - (g) the physical address of the premises and the name and postal address of the occupant.
- (2) A certificate of registration -
- (a) is not transferable between premises;
 - (b) may not be issued by the Chief Fire Officer for a period exceeding 12 months;
 - (c) may be transferred to the new owner of the premises in respect of which it was issued, only if an application for such transfer is approved by the Chief Fire Officer in writing.
- (3) A certificate of registration is valid only for -
- (a) the installation for which it was issued;
 - (b) the state of the premises at the time of issue; and
 - (c) for the quantities of flammable substance stated on the certificate.

38. Availability of certificate of registration at premises

The holder of a certificate of registration must ensure that the certificate is available on the premises concerned at all times for inspection by any member of the Service.

39. Fire-fighting equipment

(1) Any person who holds a certificate of registration or other authorization contemplated in these By-laws must ensure that the premises to which the authorization applies, are equipped with –

- (a) subject to the provisions of subsection (6), portable fire extinguishers –
 - (i) as specified in SANS 1567 (carbon dioxide-type), SANS 810 (dry chemical-type), SANS 1573 (foam-type) and SANS 1571 (transportable-type);
 - (ii) in such numbers as is appropriate in each section of the premises in accordance with the SANS codes applicable to the flammable substance and risk concerned;
- (b) if applicable, hose reels as specified in SANS 453 (hose reels), that are connected to a water supply –
 - (i) as contemplated in SANS 0400 (Part W); and

(ii) that enables each hose reel to maintain a minimum flow of 0,5 liters per second at a minimum work pressure of 300 kPa;

(c) if applicable, fire hydrants –

(i) with couplings as specified in SANS 1128 (Part II) (fire-fighting equipment- couplings); and

(ii) in a ratio of at 1 to every 1000 square meters or part thereof. and

(d) if applicable, in relation to any above-ground facility, a sprinkler system or deluge system that –

(i) is approved by the Chief Fire Officer; and

(ii) with the exception of temporary storage facilities, is installed in a position indicated in the building plans for the premises.

(2) Notwithstanding the provisions of subsection (1), if the Chief Fire Officer believes that there is any exceptional hazard or risk in respect of the premises concerned, he or she may -

(a) specify the type of fire extinguisher to be installed;

(b) require that a greater number of fire extinguishers be installed; and

(c) require that a fire detection or warning system be installed.

(3) The holder of any certificate of registration or other authorization contemplated in these By-laws must ensure that all fire-fighting equipment contemplated in subsection (1) -

(a) is inspected, maintained and serviced to the satisfaction of the Chief Fire Officer –

(i) by a competent, registered and appropriately qualified tradesman in accordance with the provisions of SANS 1015 and SANS 1475;

(ii) at least every 12 months;

(b) if installed outside the premises, is adequately protected from the weather; and

(c) is positioned prominently or where this is not possible, the position of the fire-fighting equipment is clearly indicated by a symbolic safety sign –

(i) in accordance with the specifications of SANS 1186; and

(ii) to the satisfaction of the Chief Fire Officer.

(iii) All fire extinguishers must be mounted on purpose made backboards at a max height of 1.2m from the floor to the handle with SANS approved signs. The signage is not allowed to be fixed with any adhesives or double sided tape. Signs for firefighting equipment must be well above the equipment (Min 1m) and visible from all directions.

40. Amendment to certificate of registration

The Chief Fire Officer may amend any certificate of registration on application by the holder.

41. Cancellation of certificate of registration

The provisions of section 24, read with the necessary changes, apply to any cancellation by the Chief Fire Officer of a certificate of registration.

42. Renewal of certificate of registration

Any application for the renewal of a certificate of registration must be submitted to the Chief Fire Officer at least 30 days prior to the expiry date of the certificate.

43. No authorization required for certain motor vehicle fuel tanks

No certificate of registration contemplated in section 35 or any other authorization contemplated in these by-laws is required in respect of flammable liquids in a fuel tank -

- (a) of any motor vehicle; and
- (b) of any stationery engine if the volume of the fuel tank does not exceed 1 000 liters.

44. Record of certificates of registration

The Chief Fire Officer must keep updated records of all premises in respect of which a certificate of registration has been issued, amended or renewed.

Volume 5**GENERAL PROVISIONS REGARDING THE USE, HANDLING AND STORAGE OF FLAMMABLE SUBSTANCES****45. General prohibitions regarding use, handling and storage of flammable substances**

(1) No person who uses, handles or stores a flammable substance or allows them to be used, handled or stored on any premises may -

- (a) do anything or allow anything to be done that may result in or cause a fire or explosion;
- (b) do anything or allow anything to be done that may obstruct the escape to safety of any person or animal during an emergency.

(2) No person may –

(a) dump or spill or allow the dumping or spilling of any flammable substance into any borehole, sewer, drain system or surface water;

(b) discard or allow the discarding of any flammable substance from any premises in any way other than by a competent person who is properly equipped and authorized to do in terms of these By-laws;

(c) make or bring any fire or device capable of producing an open flame or allow any other person to do so, within 5 meters of any place where a flammable substance is stored;

(d) use or allow to be used any device in connection with a flammable substance in any basement level of a building, other than a gas welding or cutting device, used for the sole purpose of maintenance of the building;

(e) while any person, except the driver or any other person responsible for a bus contemplated in the National Road Traffic Act, is in or on the bus –

- (i) fill or allow the filling of its fuel tank; or
 - (ii) transport or allow the transport of any flammable substance on the bus, except in its fuel tank; and
- (f) deliver or supply or allow to be delivered or supplied, any flammable substance to any premises unless the owner or person in charge of the premises is in possession of a valid certificate of registration.

46. Use, handling and storage of liquefied petroleum gas

(1) No person may use, handle or store liquefied petroleum gas in any quantity exceeding that stipulated in Schedule 2 unless –

- (a) the person is in possession of a certificate of registration contemplated in section 35; and
- (b) the use, handling and storage of the liquefied petroleum gas complies with the requirements of SANS 087, Parts 1, 3, 7 and 10.

(2) Liquid petroleum gas may only be used, handled or stored within property boundaries and in compliance with safety distances stipulated in SANS 087, Parts 1, 3, 7 and 10.

(3) Any storage of liquid petroleum gas cylinders at any service station for retail purposes must comply with SANS 087, Part 7.

(4) No liquid petroleum gas cylinder may be used, handled or stored at any public exhibition or demonstration without the prior written permission of the Chief Fire Officer.

(5) An application for permission contemplated in subsection (4) must be made in writing at least 14 days before the event concerned.

(6) The Chief Fire Officer may impose any reasonable condition on the use, handling and storage of liquid petroleum gas cylinders at a public exhibition or demonstration, including but not limited to, the number of cylinders, the manner of storage, safety distances and other safety requirements.

(7) Any person using, handling or storing any liquid petroleum gas cylinder at any public exhibition or demonstration must comply with any condition imposed in terms of subsection (6).

(8) All users must comply with SANS code regarding the storage and transportation of Liquid Petroleum Gas

47. Display of symbolic warning signs required

(1) The owner of any premises where any flammable or explosive substance is used, handled or stored must, in the affected area of the premises, display screwed and photo illuminated symbolic signs –

- (a) prohibiting smoking and open flames;
- (b) of a size and number determined by the Chief Fire Officer; and
- (c) prominently in places where the signs can be clearly observed.

(2) No person may disregard or allow to be disregarded any prohibition on a symbolic sign displayed in terms of subsection (1).

48. Duty to report fires, accidents and dumping

If any fire, accident or dumping involving a flammable substance has caused damage to any person, animal, property or the environment on any premises, the owner or occupier of the premises must immediately report it to the Chief Fire Officer.

VOLUME 6**STORAGE OF FLAMMABLE SUBSTANCES****49. Storage of flammable substances prohibited in certain circumstances**

No person may store or allow the storage of any flammable substance in any storeroom unless –

- (a) that person has a certificate of registration contemplated in section 35; and
- (b) the storeroom complies with the requirements of these By-laws and any other applicable law.

50. Symbolic safety signs must be displayed – (screwed and photo illuminascent)

The holder of a certificate of registration for a storeroom to be used for any flammable substance must ensure that-

- (a) symbolic safety signs prohibiting open flames and smoking are displayed in the storeroom –

- (i) of a number determined by the Chief Fire Officer;
- (ii) of dimensions at least 290 millimeters by 200 millimeters; and
- (iii) manufactured in accordance with SANS 1186;

- (b) the groups of flammable substances and their corresponding quantities which may be stored in the storeroom are indicated on the outside of every door to the storeroom in red letters at least 75 millimeters high, against a white background.

51. Construction of flammable substance storerooms

Every storeroom must be designed and constructed according to the following criteria:

- (a) The storeroom floor must consist of concrete;
- (b) the storeroom walls must consist of material that has a fire resistance of at least 120 minutes;
- (c) the storeroom roof must consist of –
 - (i) reinforced concrete with a fire resistance of at least 120 minutes; or
 - (ii) any other non-combustible material, if the storeroom -
 - (aa) boundary of the premises; or
 - (bb) adjoins a higher wall with no opening within 10 meters is not situated within 5 meters of any adjacent building or above and 5 meters on either side of the storeroom.

52. Requirements for storeroom doors

- (1) Every storeroom must be equipped with a fire rated fire door that -

- (a) is manufactured and installed in accordance with SANS 1253;
 - (b) opens to the outside;
 - (c) is equipped with a lock or locks approved by the Chief Fire Officer; and
 - (d) is at all times capable of being opened from the inside of the storeroom without the use of a key.
- (2) A storeroom must be equipped with two or more fire doors if the distance to be covered from any part in that storeroom to a door is 4 meters or more, in which case, the fire doors must be installed as far from each other as is practicable in the circumstances.
- (3) Fire doors contemplated in subsections (1) and (2) must if installed on –
- (a) external walls, be “B” class fire doors; and
 - (b) internal walls in communication within a building, be “D” class fire doors.

53. Requirements for storeroom windows

- (1) Every storeroom window frame must -
- (a) consist of steel;
 - (b) have window panels of dimensions not exceeding 450 millimeters x 450 millimeters; and
 - (c) be fitted with wire glass of a thickness not less than 8 millimeters.
- (2) No storeroom window must be capable of being opened.
- (3) Every storeroom window must be fitted to the external wall of a building.

54. Requirements for storeroom catch pits

- (1) Every storeroom must be designed and constructed so that its floor is recessed below the level of the door sill to form a catch pit -
- (a) with a holding capacity at least equal to the total volume of hazardous substances capable of being stored in the storeroom, plus 10 percent; and
 - (b) if required by the Chief Fire Officer –
 - (i) covered at door sill level by a strong, stable, non-combustible and oxidation free floor grill; and
 - (ii) equipped, at its lowest level, with a non-corrosive drainage valve for cleaning purposes and product recovery.
- (2) The floor grill contemplated in subsection (i) must contain a suitably positioned access hatch for cleaning purposes.

55. Ventilation of storerooms

- (1) Every storeroom must be designed and constructed to ensure -
- (a) the effective ventilation of flammable substance fumes;

(b) that fumes released from the storeroom into the open air will not come into contact with any source of ignition.

(2) If the storeroom is designed and constructed for natural ventilation, the owner or person in charge of the storeroom must ventilate the storeroom at a minimum cycle of 30 air changes per hour by installing non-combustible airbricks –

(a) that are not less than 140 millimeters by 250 millimeters in extent, with non-corrosive gauze wire with a minimum opening diameter of 0.5 millimeters;

(b) that are provided in at least 3 external walls of the storeroom; and

(c) that are positioned 100 millimeters above the level of the sill and 100 millimeters below the level of the roof and not more than 450 millimeters apart.

(3) If the storeroom is designed and constructed for mechanical ventilation, the owner or person in charge of the storeroom must equip it with a mechanical ventilation system –

(a) designed and installed for this purpose;

(b) with a flow rate of 0,5 meters / second across the store;

(c) with vanes that consist of a static-free material;

(d) that discharges through a vertical metal duct into the open air –

(i) not situated within 5 meters of any opening of a building or erf boundary; and

(ii) terminating at least 1 meter above roof height or at least 3.6 meters above ground level, whichever is the greater;

(e) equipped with ventilators that are firmly attached to the inside of the walls of the storeroom and, in the case of bottom ventilators, as close as possible to the level of the sill;

(f) with all ventilation or air duct openings in the external wall opposite the mechanical ventilator installed 100 millimeters above the level of the sill to ensure effective cross-ventilation; and

(g) equipped with ducting material that –

(i) is as short as possible in the circumstances and does not have sharp bends; and

(ii) is fitted with a fire damper of at least 120 minutes fire resistance at any point where the ducting exits the storeroom, if ducting material is installed external to the storeroom in communication with the remainder of the building.

56. Electrical equipment in storerooms

(1) The owner or person in charge of any storeroom must ensure that -

(a) all electrical apparatus, fittings or switch gear used or installed in the storeroom are used or installed as contemplated in SANS 0108;

(b) no switch gear, distribution box, fuse or other electrical equipment, except electrical equipment as contemplated in SANS 0108, is situated –

- (i) inside the storeroom; or
 - (ii) in any position where it may come into contact with any flammable substance fumes leaving the storeroom;
 - (c) any metal part, electrical fittings and device used in or in connection with the storeroom are earthed effectively to each other and to the ground;
 - (d) any mechanical ventilation system switch is situated outside the storeroom;
 - (e) any mechanical ventilation system is on at all times, except when the system is being repaired or replaced, in which case the system must be repaired or replaced without delay; and
 - (f) all electrical apparatus and fittings, except the mechanical ventilation system, are switched off when the storeroom is unattended.
- (2) Any electrical installation in a storeroom may be installed and certified only by an electrician who is qualified and competent by virtue of his or her training and experience.
- (3) The owner or person in charge of a storeroom must submit the certificate contemplated in subsection (2) to the Chief Fire Officer for record purposes immediately after installation contemplated in that subsection.

57. Foam inlets required for certain storerooms

The owner or person in charge of a storeroom that is used or intended to be used for storing more than 5000 liters of flammable substance must ensure -

- (a) that the storeroom is provided with a foam inlet consisting of a 65 mm male instantaneous coupling and mild steel pipe work leading to the inside thereof; and
- (b) that the foam inlet is identified by a sign in block letters at least 100 millimeters high, displaying the words "foam inlet".

58. Shelving in storerooms

The owner or person in charge of a storeroom must ensure that any racking of shelving erected or installed in the storeroom is of non-combustible material.

59. Unauthorized use and entry of storerooms prohibited

No person may –

- (a) without the authority of the owner or person in charge, enter or allow any other person to enter any storeroom;
- (b) use any storeroom or allow it to be used for any purpose other than for the use, handling or storage of flammable substances;
- (c) allow any person to work in a storeroom unless all the doors of the storeroom are wide open or the mechanical ventilation system is switched on; or
- (d) place or allow to be placed any obstruction or hindrance in a passage of any storeroom or in front of any storeroom door.

60. Mixing and decanting rooms

60. The owner or person in charge of any premises where quantities of flammable liquids exceeding those stipulated in Schedule 3 are decanted or mixed, must ensure that any room where decanting or mixing takes place complies with all requirements of this Chapter applicable to storerooms.

61. Temporary above ground storage of flammable substances

(1) Any person who wishes to store any flammable substance on premises on a temporary basis, must apply to the Chief Fire Officer for a temporary certificate of registration.

(2) A temporary certificate of registration may be issued by the Chief Fire Officer -

(a) for a period not exceeding 12 months;

(b) if the flammable substance concerned is required -

(i) in respect of excavation work, construction work or road construction if the volume of the flammable substance does not exceed 9 000 liters;

(ii) in respect of small fleet maintenance or research purposes, if the volume of the flammable substance does not exceed 4 400 liters; and

(iii) the application complies with the requirements of SANS 0131 and this Chapter.

(3) Every holder of a temporary certificate of registration contemplated in subsection (1) must ensure that -

(a) a storage tank for the flammable substance is not erected within 3.5 meters of any erf boundary, building, excavation, road, driveway or any other flammable substances or combustible material;

(b) adequate provision is made for rainwater run-off from retaining walls or embankments;

(c) no source of ignition or potential source of ignition exists within 5 meters of a storage tank;

(d) a symbolic sign of dimensions at least 300 millimeters by 300 millimeters prohibiting smoking and open flames is displayed on every side of a temporary storage tank; and

(e) at least two 9 kilogram dry chemical fire extinguishers are installed and kept in good working condition, within 10 meters of a temporary storage tank.

62. Hand tools must be intrinsically safe

The owner or person in charge of any flammable substance storeroom must ensure that any hand tool used in the storeroom is intrinsically safe.

63. Permanent above ground storage tanks for flammable liquids

(1) In addition to any other requirement of this Chapter, the owner or person in charge of an above ground storage tank for flammable liquids must ensure -

(a) that the tank is erected or installed -

(i) in accordance with SANS 0131 and SANS 089, Part I;

(ii) at least 3.5 meters from any erf boundary, building, excavation, road, driveway or any other flammable substance, combustible substance or combustible material;

(b) that the flammable liquid stored in the tank must be clearly identified by means of Hazchem placards contemplated in SANS 0232, Part 1.

(c) No flammable liquids shall be permitted in a residential area provided that it is used for domestic purposes.

(2) Any electrical installation associated with the storage tank must comply with SANS 0108 and SANS 089, Part 2.

(3) No person shall store or handle more than 5 000 litres of flammable liquids Class II or III above ground except in a bulk storage facility.

(4) Sub-section (3) the proposed area for bulk storage must be approved by the Chief Fire officer in considering the risk associated to area. The Chief Fire Officer has got a power to disapproved the area when it will cause a risk to the inhabitants, properties etc.

(5) Installing of above ground tankers must be install with sprinklers system surrounding the tanker to form a sprinkler curtain during fire.

64. Underground storage tanks for flammable liquids

The owner or person in charge of any premises used or intended to be used for the underground storage of any flammable liquid must ensure that any underground storage tank, pump, dispenser and pipe work is erected or installed in accordance with SANS 0400, SANS 089, Part 3 and SANS 0131.

65. Installing, erecting, removing and demolishing prohibited without prior notice

(1) No person may, in respect of registered premises, erect, install, remove, demolish, extend or change any delivery pump, storage tank, storeroom, spraying room, gas installation, storage facility, fire protection arrangement or floor layout unless that person has given the Chief Fire Officer at least three working days prior written notice of the intention to do so, in the form and manner determined by the Council.

(2) The notice in term of subsection (1) must include the intended commencement date and estimated completion date of the proposed work.

(3) The provisions of subsection (1) do not apply to –

(a) the temporary removal of equipment for purposes of carrying out necessary repairs;

(b) the necessary replacement of equipment or their parts; and

(c) the replacement of any storage tank with a tank of the same capacity.

66. Repair and maintenance of access to storage tanks

No person may enter or allow any other person to enter any storage tank that has at any time contained a flammable substance -

(a) until such tank has been de-aerated and made free of gas and fumes as contemplated in SANS 089 (Part I); or

(b) unless that person –

(i) is wearing an effective self-supporting breathing apparatus; and

(ii) is attached to a rescue rope under the control of a competent and responsible person.

67. Termination of storage and use of flammable substances

(1) If an aboveground or underground tank installation, liquid petroleum gas installation or associated pipe work is no longer required for the storage or use of a flammable substance, the owner or person in charge of the premises on which the installation is located, must -

(a) notify the Chief Fire Officer in writing within seven days of such storage or use ceasing;

(b) ensure that the flammable substance is removed from the installation and the premises are rendered safe within 30 days of the cessation;

(c) unless the Chief Fire Officer directs otherwise, remove the installation including any associated pipe work from the premises within 180 days of the cessation; and

(d) to the satisfaction of the Council, restore any public foot path or roadway that has been disturbed by the removal of the installation within a period of 7 days of completing such removal.

(2) Notwithstanding the provisions of subsection (1) if the removal of any underground tank installation for the storage of a flammable substance will detrimentally affect the stability of the premises concerned, the owner or person in charge of the installation may, with the prior written permission of the Chief Fire Officer, fill the underground tank with liquid cement slurry.

68. Container handling and storage

(1) Every flammable substance container must -

(a) be kept closed when not in use;

(b) be declared gas- or vapor-free by a competent person before any modification or repairs are undertaken;

(c) be manufactured and maintained in such condition as to be reasonably safe from damage and to prevent leakage of any flammable substance or vapor from the container.

(2) Every flammable liquid container must be labelled and marked with words and details indicating the flammable liquid contained in the container as well as any hazard associated with the flammable liquid.

(3) No person may extract flammable liquid from a container of a capacity exceeding 200 liters, unless the container is fitted with an adequately sealed pump or tap.

(4) Any empty flammable liquid container must be stored in a storeroom.

(5) Notwithstanding the provisions of subsection (4) the Chief Fire Officer may permit the storage of any empty flammable liquid container in the open air if no storeroom is available and if he or she is satisfied that -

(a) the storage area is in a position and of sufficient size that a fire hazard or other threatening danger will not be caused;

(b) the storage area is well ventilated and enclosed by a wire mesh fence;

(c) the fence supports are of steel or reinforced concrete;

(d) the storage area has an outward opening gate that is kept locked when not in use;

(e) when the floor area exceeds 10 m² an additional escape gate is installed and fitted with a sliding bolt or other similar locking device that can be opened from the inside without the use of a key; and

(f) the storage area is free of vegetation and has a non-combustible, firm and level base.

(6) When the quantity of flammable and combustible liquids to be stored is more than 100 litres of class I and/ or more than 210 liters of class II and class III, a combined, such flammable and combustible liquids must be stored in a store room.

VOLUME 7

TRANSPORT, SUPPLY AND DELIVERY OF DANGEROUS GOODS

69. Transport of dangerous goods prohibited without permits

The owner of any vehicle used for transporting dangerous goods, must -

(a) be in possession of a valid transport permit issued by the Chief Fire Officer in accordance with the National Road Traffic Act; and

(b) ensure that the transport permit is available in the vehicle for inspection at all times.

70. Application for transport permits

An application for a transport permit must be completed and submitted to the Chief Fire Officer in the form and manner determined by the Council together with the prescribed fee.

71. Requirements of transport permits

A transport permit -

(a) may not be issued by the Chief Fire Officer for a period longer than 12 months; and

(b) must –

(i) indicate the date of issue and expiry;

(ii) identify the issuing officer and bear that officer's signature;

(iii) contain a serial number;

(iv) indicate the group and quantity of dangerous goods that may be transported under the permit; and

(v) contain a description of the vehicle concerned, including its registration number.

(vi) valid from the date issued

72. Cancellation of transport permit

The provisions of section 24, read with the necessary changes, apply to any cancellation of a transport permit by the Chief Fire Officer.

73. Exemption from transport permits

A transport permit contemplated in section 69 is not required for the transportation of dangerous goods of the type and not exceeding the quantities stipulated in Schedule 3.

74. Design, construction, maintenance and repair of road tankers

Every person who designs, constructs, maintains or repairs any road tanker for the transportation of dangerous goods must -

(a) comply with the provisions of SANS 0189, SANS 1398, SANS 0233, SANS 087, Part 6 SANS 089, Part 1, SANS 0230 and SANS 1518, as the case may be; and

(b) ensure that the road tanker is labelled in a manner that complies with the provisions of SANS 0232 and any applicable law.

75. Design, construction, maintenance and repair of other vehicles

Every person who designs, constructs, maintains or repairs any vehicle for the transportation of dangerous goods, except a road tanker, must ensure that the vehicle –

(a) is designed and constructed –

(i) to safely transport the quantity and type of dangerous goods for which the vehicle is intended to be used; and

(ii) with at least two independent axle systems, each with its own suspension system, excluding any trailer forming part of an articulated vehicle;

(b) is equipped with –

(i) a safety edge or safety railing -

(aa) at least 1 meter high when measured from the surface of the body of the vehicle; and

(bb) capable of securing dangerous goods containers;

(ii) strong and durable straps -

(aa) capable of fastening dangerous goods containers securely to the body of the vehicle;

(bb) that are anchored firmly to the bodywork of the vehicle; and

(cc) that are fitted with a reversible cog winch mechanism that can be locked;

(iii) electrical wiring that complies with SANS 314;

(iv) at least 2 static-free wheel blocks;

(v) a power insulating switch, excluding the ignition switch, situated in close proximity to the vehicle battery and in a position readily accessible in any emergency; and

(vi) a spark-proof and static-free tank that is designed, constructed and equipped to protect any dangerous goods consignment from shock or ignition while in transit.

76. General prohibitions regarding transport of dangerous goods

(1) No person may use or allow to be used, any vehicle to transport dangerous goods, unless –

(a) the vehicle has a valid roadworthy certificate;

(b) if not exempt in terms of section 73, the vehicle is equipped with at least two 9 kilogram dry chemical fire extinguishers -

(i) designed and manufactured in accordance with SANS 810 and maintained in accordance with SANS 0105 and SANS 1475; and

(ii) positioned and installed so that there is at least one fire extinguisher on each side of the vehicle that can be reached quickly and easily in the event of a fire.

(2) No person may use or allow to be used any vehicle to transport dangerous goods unless the vehicle cabin, body, cargo space, cargo tank, fuel tank, chassis and engine are effectively and permanently earthed with each other

77. Supply of dangerous goods prohibited in certain circumstances

(1) No person may deliver or supply or allow to be delivered or supplied any dangerous goods of a type and in a quantity exceeding that specified in Schedule 2 to any premises that are not registered as contemplated in section 35.

(2) No person may deliver or supply or allow to be delivered or supplied any dangerous goods to any premises in contravention of any conditions of the certificate of registration applicable to those premises.

(3) No person may handle or allow to be handled any container containing dangerous goods in a manner that may damage that container.

(4) Every person who delivers dangerous goods must ensure that -

(a) a 9 kilogram dry chemical fire-extinguisher is available at all times during the delivery;

(b) during any transfer of the dangerous goods, the delivery vehicle is physically earthed to the storage facility to which the dangerous goods are being transferred;

(c) while delivering –

(i) the delivery vehicle is placed in such a position that it can be moved easily and quickly in the event of an emergency;

(ii) the delivery vehicle is not parked on or across a pavement or a road;

(iii) no delivery hose lies on or across a pavement, road or other premises;

(d) no dangerous goods are transferred to a storage facility that does not comply with the requirements of Chapter 6 and the provisions of SANS 0263;

(e) any device connected with, or used for, the delivery of the dangerous goods -

(i) is designed for its purpose; and

(ii) is maintained in safe and good working condition; and

(f) no dangerous goods are spilled during delivery.

(5) No person may transfer or allow to be transferred any dangerous goods to any motor vehicle, aircraft, vessel, ship or boat while its power source is in operation.

(6) No person may transfer any dangerous goods to any aircraft unless the aircraft is earthed to the transferal device by means of an earth cable.

78. Records of transport permits

The Chief Fire Officer must keep updated records of all vehicles in respect of which a transport permit has been issued, amended or renewed.

VOLUME 8

SPRAY PAINTING

79. Spraying prohibited without spraying permit

(1) No person may spray, coat, plate or epoxy-coat any vehicle, article, object or building or part thereof or allow them to be sprayed, coated, plated or epoxy-coated with any flammable substance unless -

(a) that person is in possession of a spraying permit contemplated in section 80;

(b) the spraying, coating, plating or epoxy-coating as the case may be is conducted in a spraying room approved by the Chief Fire Officer on premises registered for that purpose.

80. Application for spraying permit

Any person who wishes to obtain a spraying permit must -

(a) complete and submit to the Chief Fire Officer an application form for such permit in the form and manner determined by the Council; and

(b) pay the prescribed fee.

81. Cancellation of spraying permit

The provisions of section 24, read with the necessary changes, apply to the cancellation by the Chief Fire Officer of any spraying permit.

82. Duties of owner, occupier or person in charge of spraying room

Every owner, occupier and person in charge of a spraying room must ensure that -

(a) the spraying room complies with the requirements of this Chapter; and

(b) every other person on the premises complies with the provisions of this Chapter.

83. Design and construction of spraying rooms

(1) Every spraying room must be designed and constructed according to the following criteria:

(a) every window frame must consist of steel with window panels -

(i) that cannot be opened;

(ii) that do not exceed 450 millimeters x 450 millimeters in size; and

(iii) that are fitted with wire glass with a thickness not less than 8 millimeters;

(b) if based on a brick and concrete construction -

(i) the floor must consist of concrete;

(ii) the walls must consist of brick or concrete;

(iii) the roof must consist of reinforced concrete; and

(iv) every door must consist of a Class B-type fire doors as contemplated in SANS 1253; and

(c) if based on a metal structure –

(i) the framework of the structure, including door assemblies must consist of a sturdy steel profile with a minimum wall thickness of 2.5 millimeters;

(ii) the framework of the entire structure, including any door, must be clad on both sides with sheet metal with a minimum thickness of 1.3 millimeters;

(iii) the framework of the entire structure must be fume-proof, flame-proof and liquid-proof;

(iv) the floor must consist of concrete or metal;

(v) all material used must have a fire integrity grading of at least 60 minutes; and

(vi) the structure must be constructed, installed and finished so that all surfaces are smooth in order to prevent any furring which may hamper ventilation, washing or cleaning of the spraying room.

84. Water floors for spraying rooms

Every spraying room which is designed and constructed with a sunken water floor must be designed and constructed so that -

(a) the water is covered at the level of the sill by a sturdy, stable, non-combustible and corrosion-free floor grill capable of bearing the weight of every person and object in the spraying room; and

(b) the water in the sunken water floor is circulated through an effective non-combustible and cleanable filtering system by a closed circuit pump circulation system consisting of non-corrosive metal pipes of suitable diameter and wall thickness.

85. Electrical equipment in spraying rooms

(1) Any electrical apparatus, light, fitting and switch gear installed or used in a spraying room must be installed and used in accordance with SANS 0108.

(2) Any switch gear, distribution box, fuse and other electrical equipment, except equipment as contemplated in SANS 0108 must -

(a) be located outside the spraying room; and

(b) be positioned so as not to come into contact with fumes from the spraying room.

(3) Any switch for the mechanical ventilation system of a spraying room must be situated outside the spraying room.

(4) Any metal part and electrical fitting and any other device used in, or in connection with, the spraying room, must be earthed effectively with each other and the ground.

(5) Every electrical installation in a spraying room may be installed only by a suitably qualified electrician who must -

(a) certify in writing that the installation complies with all applicable legal requirements; and

(b) furnish the certificate to the owner or person responsible for the premises concerned.

(6) The owner or person responsible for the premises on which the spraying room is located must submit the certificate contemplated in subsection (5) to the Chief Fire Officer without delay.

86. Location of spraying rooms

(1) The owner, occupier and person in charge of a spraying room must ensure that there is an escape opening between the spraying room and any other activity, process or area on the premises concerned -

(a) of at least 1200 millimeters wide; and

(b) that must at all times be kept free of any obstruction, refuse or combustible material.

(2) If any other activity or process which may pose a fire hazard is conducted adjacent to a spraying room on any premises, the escape opening contemplated in subsection (1), must be clearly identified by a fire partition wall –

(a) of a height at least 300 millimeters higher than the roof of the spraying room; and

(b) with a fire resistance of at least 60 minutes.

(3) No more than two sides of a spraying room contemplated in section 83(1)(c), may border a fire partition wall.

87. Access to spraying rooms

In addition to any door for the access of motor vehicles or other objects to any spraying room, every spraying room must have at least two hinged doors for escape purposes that –

(a) open to the outside of the spraying room;

(b) have dimensions of at least 800 millimeters wide x 2000 millimeters high;

(c) are positioned on opposite sides of the spraying room so that the distance to be covered to any door when any object is in the spraying room for spraying does not exceed 4 meters; and

(d) are fitted with a locking mechanism that is at all times capable of being opened from the inside of the spraying room without the use of a key.

88. Ventilation of spraying rooms

Every spraying room must be equipped with a mechanical inlet and outlet ventilation system designed and installed -

(a) so that ventilation of at least 0.5 meters per second is provided across the spraying room;

(b) with vanes consisting of static-free material;

(c) so that it releases fumes into the open air from outlets that are not located within 5 meters of any opening of a building or erf boundary;

(d) with ventilators that are attached firmly to the inside walls of the spraying room with bottom ventilators affixed as close as possible to the level of the sill;

(e) with ventilation and air duct openings installed in opposite walls, doors or the roof so as to ensure effective cross-ventilation; and

(f) with ducting material that is fitted with a fire damper and covering of at least 120 minutes fire resistance where the ducting material exists the spraying room, if ducting material is installed external to the spraying room in communication with the remainder of the building concerned.

89. Fire dampers, protectors and alarms in spraying rooms

(1) A fire damper manufactured and installed in accordance with SANS 193, must be affixed in front of any air purification filter or part of such filter on the inside of any spraying room.

(2) The fire damper must –

(a) be capable of closing automatically by means of a suitably located sensor that is activated by a rise of more than 10oC in the predetermined working temperature inside the spraying room;

(b) be installed so that it will remain in position even if the air duct distorts during a fire; and

(c) be equipped with an overriding fusible link.

(3) The ventilation system must be equipped with a sensor that -

(a) is capable of turning off the ventilation system and any heating device used in connection with the spraying room, in the event of a fire or a rise of more than 10oC in the predetermined working temperature inside the spraying room; and

(b) activates a visual and audible alarm inside and outside the spraying room in an event contemplated in paragraph (a).

90. Design and positioning of ventilation outlets for spraying rooms

Every outlet opening from a spraying room must be designed and positioned to release fumes from the spraying room into the open air at least -

(a) 1 meter above any roof on the premises;

- (b) 4 meters above the ground level; and
- (c) 5 meters from any opening of a building situated on or adjacent to the spraying room.

91. Display of signs on spraying rooms (screwed and photo illuminated)

- (1) A symbolic sign prohibiting open flames and smoking must be affixed to the inside and the outside of every door of a spraying room.
- (2) Any symbolic sign contemplated in subsection (1), must be –
 - (a) manufactured and installed in accordance with SANS 1186; and
 - (b) of dimensions at least 290 millimeters by 290 millimeters.

92. Manifold installations in spraying rooms

Every manifold installation of a Group II hazardous substance that forms an integral part of the heating system of any spraying room must -

- (a) comply with SANS 087 (Part 1); and
- (b) the requirements of these By-laws.

93. General prohibitions regarding spraying rooms

No person may –

- (a) use any spraying room or allow any spraying room to be used unless signs prohibiting open flames and smoking are affixed to the spraying room in compliance with section 91;
- (b) enter a spraying room or allow any other person to enter a spraying room without the authority of the owner, occupier or person in control of the spraying room;
- (c) use any spraying room or allow any spraying room to be used for any purpose other than spray painting or related activities;
- (d) enter any spraying room or allow any other person to enter a spraying room unless the mechanical ventilation system is operating; or
- (e) place any obstruction of hindrance or allow any obstruction or hindrance to be placed in any escape opening or in front of any door of a spraying room.

94. Fire extinguishing equipment in spraying rooms

- (1) Every spraying room must be equipped with -
 - (a) at least one 9 kilogram dry chemical fire extinguisher installed on the inside of the spraying room; and
 - (b) at least one 9 kilogram dry chemical fire extinguisher installed on the outside of the spraying room.
- (2) Fire extinguishers contemplated in subsection (1) must be installed in positions approved by a member of the Service.
- (3) Every spraying room must be protected by at least one fire hose reel as specified in SANS 543 -

- (a) that is connected to a water supply as contemplated in SANS 0400 (Part W); and
- (b) that enables the hose reel to maintain a flow of at least 0.5 liters per second at a work pressure of at least 300 kPa.

VOLUME 9

FIRE BRIGADE SERVICES

95. Establishment and maintenance of Service

(1) The Council has established a Fire Brigade Service as contemplated in section 3 of the Fire Brigade Services Act.

(2) The Council must maintain the Service, which includes -

(a) appointing a Chief Fire Officer and the necessary members of the Service;

(b) ensuring that they are properly trained; and

(c) acquiring and maintaining the necessary vehicles, machinery, equipment, devices and accessories to ensure that the Service is effective and able to fulfil its objects.

(3) That the Council and by association the Fire and Emergency Services, in effect can rely if required on the participation and assistance from other relevant roll players/stake holders in the area meaning other emergency and ambulance services.

(4) The appointed Chief fire Officer as stipulated on 2(a) may at any reasonable time enter any premises in the area of the controlling authority concerned in order to determine whether the provisions contemplated in Fire Brigade act, sections 15 (1) (a), (d), (e) and (g) and 16 are being complied with.

96. Objects of service

The objects of the Service are –

(a) to prevent the outbreak and spread of fire;

(b) to fight and extinguish any fire that endangers any person or property;

(c) to protect any person and property against any fire hazard or other danger contemplated in these By-laws; and

(d) to rescue any person and property from any fire or other danger contemplated in these By-laws.

97. Services to other persons

(1) The Service may, provide any service related to its objects to any other person against payment of the prescribed fee, as outline from Municipal Financial Management Act section 97

(2) Any service contemplated in subsection (1), may be terminated without notice if the services, equipment or personnel involved in providing that service are required to deal with an emergency.

98. Instructions by members of Service

(1) In addition to any powers under section 8 of the Fire Brigade Services Act, a member may give any instruction to any person in order to secure compliance with these By-laws or to ensure the safety of any person or property.

(2) An instruction may be given orally or in writing and if the instruction is given orally, the member must confirm it in writing and give it to the person concerned at the earliest opportunity.

(3) An instruction contemplated in subsection (1) may include, but is not limited to an instruction -

(a) for the immediate evacuation of any premises;

(b) to close any premises until such time as any contravention of these By-laws has been rectified;

(c) to cease any activity;

(d) to remove any immediate threat to the safety of any person or property;

(e) to take specified steps to comply with these By-laws, either immediately or within a specified period; and

(f) if it is not reasonable for steps referred to in paragraph (e), to be taken immediately, for the owner or occupier of the premises concerned to provide the Chief Fire Officer with a written description of the steps to be taken and a time-table for the taking of these steps in order to ensure compliance with these By-laws.

99. Pretending to be member of Service prohibited

(1) No person may pretend to be a member.

(2) No person who is not a member may wear any official clothing, uniform, badge or insignia of the Service.

100. Certificates to identify members of Service

(1) The Chief Fire Officer must provide each member with a certificate identifying that person as a member.

(2) A member, while performing any function or exercising any power under these By-laws must –

(a) keep the certificate provided in terms of subsection (1), on his or her person; and

(b) produce it for inspection on request by any person.

101. Cost of analysis samples

(1) Any costs incurred by the Council in connection with the analysis of any sample taken from any premises for the purposes of these By-laws, and a report on such analysis by an institution accredited by the Chief Fire Officer for that purpose may be recovered from the owner or occupier of that premises if the owner or occupier of the premises is not in compliance with these By-laws regarding the substance concerned.

VOLUME 10**102. Event management**

The Mbombela Fire, Rescue and Emergency Services and by association, the Mbombela Local Authority, are mandated to perform specific functions at certain events with regards to fire related matters in order to secure the well-being and safety of all patrons and property attending sports, recreational, religious, cultural, exhibitions or similar events.

102. Roles and Responsibilities

The Chief Fire Officer from the Mbombela Fire and Rescue Services shall, as a member of the Safety and Security cluster, ensure that:

- (1) the Chief Fire Officer, or an appointed member of the Mbombela Fire and Rescue Services, attend Safety and Security plenary meetings pertaining the event as arranged by the authorized member providing that a reasonable arrangement was made in terms of timeous notification.
- (2) the lawful requirements and stipulations in relation to the Fire Services Act., and the fire related sections of the Mbombela Local Municipality By-laws, are complied with.
- (3) within reason, assistance and support is given to other Departments and members of the Safety and Security Cluster.
- (4) the necessary fire safety measures and steps, meaning the implementation of related By-laws and lawful legislation, inspections, deployment, etc. be taken based on the risk profiling and assessment as well as event demographic, to ensure the safety of consumers and property at the event.
- (5) the Safety and Security Committee/Cluster is informed about fire related risks and conditions that could threaten the well-being and safety of people and property at the event.
- (6) fire related threats and dangerous conditions, or conditions that could possibly pose a threat or danger to the event, be noted to the Committee. These threats or conditions are to be negotiated or mediated if possible. If negotiation or mediation with regards to the threat or danger is not possible, other plans/options will be imposed by the Chief Fire officer.
- (7) if the provisions in terms of Section 6 cannot be met, meaning the submission of other plans/options, that the cancellation or the postponement of the event be considered.
- (8) the Safety and Security Committee/Cluster be provided with an initial deployment figure in terms of staff and resources that will do standby at the event. If there is no need for the Fire and Rescue Services to deploy for whatever reason, the Chief Fire Officer or the appointed representative, will make a confirmation to the effect.
- (9) that direction is received in terms of accreditation for staff members and vehicles that will perform standby duties at the event.
- (10) the name and contact details of a senior staff member representing the Fire and Rescue Services in the VOC during the event, be submitted to the Committee/VOC Commander/Authorized member.

- (11) that the overall emergency plan of the event be made available on request by the event organizer. The plan must include the evacuation plan with assembly areas, escape routes, exits, alternative routes for emergency vehicles, etc.

103. Deployment at events

The Chief Fire Officer or appointed representative shall take a decision regarding the deployment of resources to the event based on the following:

- (1) Venue layout and construction (building, tents, portable structures, open air).
- (2) Actual fire risk at the event.
- (3) Fire related threats and dangerous conditions.
- (4) Event demographic (music festival, sports, religious, exhibition, etc.).
- (5) Crowd demographic (old age, adults, children, male, female, intoxicated).
- (6) Crowd size (number of patrons).
- (7) Area of precinct/event in square meters.
- (8) Amount and width of exits from the affected area.
- (9) Time of the year, month, week or day.
- (10) Duration of the event.
- (11) Other threats or dangerous conditions that could have impact on the safety of the event, from inside the precinct/venue or from outside.
- (12) VIP or important political figures attending the event.
- (13) Availability of resources in terms of equipment, staff members and vehicles.

104. Special or elevated risks to an event

Any threat, condition or situation that could cause major disruption to the event resulting in, or has the possibility to result in large scale injuries to people, loss of life or damage to property.

(1) Fireworks

The organizer of the event shall apply in advance to the Chief Fire Officer for approval to have a fireworks display at an event as per Section 32 of the By-laws. The Chief Fire Officer will make a decision regarding the approval, the deployment of staff and vehicles if so required, and the service fee of such deployment.

(2) Natural disasters

The Safety and Security Committee and the event organizer should take notice of conditions during the plenary meetings for the event, as well as foresee conditions that could have an

effect on the event and plan accordingly. The weather forecast is therefore of utmost importance as most natural disasters are due to adverse weather conditions. Conditions that could cause a high fire index (dry and windy), strong winds, excessive rainfall (flooding), hail, extreme heat, etc.

The Safety and Security Committee/Cluster and event organizer will rely heavily on accurate information as provided by the representative from the Weather Services in this regard.

(3) Political unrest or protests

The Security and Safety Committee/Cluster should give cognizance to any political situation and possible protest action that could have an impact on the event. The relevant intelligence agencies from the South African Police Service should provide the Committee with updated information regarding and the necessary planning should be made accordingly.

(4) Helicopter rides, landings and take-offs

The Chief Fire Officer will give permission for any landing of helicopter in the City of Mbombela and the following safety requirements must be followed

1. Written authorization from the organizer of the event, or custodian/owner of the premises.
2. Authorization from the Mbombela Traffic Department.
3. A clear landing area of not less than 50m x 50m. This dimension could change depending on the event demographic and/or other conditions.
4. The landing area to be clearly indicated.
5. Notification boards/signs to be displayed to warn the public not to approach the landing area.
6. Members of public around the landing site should be managed and directed by qualified fire marshals who have knowledge regarding basic first aid and fire-fighting.
7. 2 x 9 kg Dry Chemical Extinguishers (serviced) to be placed on opposite sides of the landing site perimeter.
8. The Chief Fire Officer may, based on risk factors, decide that more safety measures be in place, or not. The Chief Fire Officer may also decide, as a mitigation factor, to place a Fire Engine and crew on site in which case the normal call out rate (services fee) will apply.
9. That the information/notification/ for an aircraft landing at events be forwarded to the Mbombela Fire and Rescue Services as soon as possible. Preferably two (2) weeks in advance.

(5) Bees

If an event is invaded/targeted by a swarm of bees, EMS should be notified with immediate effect through the VOC structure and medical facilities, hospitals and clinics must be put on high alert. Depending on the mood of the bees, the size of the swarm and the area affected,

evacuation of the said area should be considered. If the invasion/attack persist or the situation worsens, total evacuation of the area must be considered. If the situation becomes **uncontrollable, postponement or cancellation of the event must be considered.**

- (6) Any other unforeseen condition or situation that could cause major disruption to the event that could result in injury, loss of life and property, should be identified as early as possible by the Safety and Security Committee/Cluster, negotiated, and mediated. If negotiation, mediation and secondary planning fails, postponement or cancellation of the event must be considered.

105. Stalls and Venders

In order to provide for a safe environment for the public, stall and vender owners at inside and outside events in the Mbombela Local Municipality area, the following requirements are to be complied with. The event organizer should ensure that the requirements are made known to the affected parties prior to the event.

- (1) Every food stall or vender holder that makes use of a gas operated appliance or open flames, will have a fire extinguisher not smaller than a 4.5 kg Dry Chemical Powder in capacity in his/her stall and should also have the knowledge and capacity to operate the device. This requirement extends to any stall holder, vender holder, or person that is responsible for making a fire at the event for whatever reason.
- (2) Gas cylinders must be a reasonable distance, 100 cm – 150 cm from the actual ovens, stoves or burners.
- (3) The pipe work and connections on gas operated appliances shall be in good condition and in proper working order.
- (4) A gas cylinder with a maximum capacity of 19 kg is permissible inside a tent with a gas cylinder not exceeding 48 kg outside a tent. There may not be an accumulation of cylinders on the premises. Fire extinguishers shall be clearly visible, easy reachable and unobstructed at all times.
- (5) Gas cylinders shall be placed on level surface areas away from public walkways. “No Smoking”, “No Open Flame” and “No Cell Phone” signs shall be displayed where gas are being used, stored or in public walk ways.
- (6) Electrical wiring and connections shall be in good condition and tucked away neatly from possible danger areas and public walkways. Rope lighting, décor lighting, extension cords, etc. shall be well managed, out of the way, and shall be waterproofed if exposed to the elements.
- (7) All fire extinguishers shall be in good condition, operational with the device being serviced at least once within a period of twelve months.
- (8) Stall and vender holders shall ensure that there is a reasonable distance between open flames, gas operated appliances, electrical appliances or other heat sources from any

flammable materials or flammable liquids in the immediate area. The said reasonable distance could be influenced by weather conditions.

- (9) Event organizers, stall holders and vender holders shall ensure that there is an open space of 5 meters between tents or structures larger than 400 square meters to prevent fire spread and allow access for emergency vehicles.
- (10) The area surrounding gas operated appliances, or open flame devices, shall be kept clean and clear of obstructions. The general house-keeping rule is applicable in terms of neatness.
- (11) Fire extinguishers and other fire-fighting equipment shall be visible and easily accessible.
- (12) No fire safety signage for extinguishers, hose reels, hydrants, exits, exit routes, etc., shall be obstructed at any time during the event.
- (13) It shall be prohibited to make any fires at an event for whatever reason, unless such an arrangement was approved in advance by the Chief Fire Officer of the Mbombela Fire and Rescue Services.
- (14) The Chief Fire Officer may adapt, or make any ruling with regards to fire related matters at the event to ensure the well-being and safety of people at an event.
- (15) Due to extraordinary circumstances and elevated risks at events by design, it is required that common sense prevail at all times.

VOLUME 11

MISCELLANEOUS

106. Handling animals during emergencies

The handling of animals during emergencies, taking in account the provisions and prohibitions of the Animals Protection Act No. 71 of 1962.

- (1) The owner, occupier or person in charge of any zoological garden, feedlot, stable, research institution, veterinary practice or any place of veterinary science study, must ensure the professional handling of any animal on the premises concerned during an emergency.
- (2) Notwithstanding the provisions of subsection (1), the Chief Fire Officer may, in respect of any premises, authorize a suitably qualified person to handle or put down any animal during an emergency.
- (3) The Council may recover any costs incurred in relation to the professional handling or putting down of any animal during an emergency from the owner or occupier of the premises concerned.

107. Exemption from provisions of these by-law

- (1) Any person may make application to the Council in writing, for an exemption from any provision of these By-laws, specifying the reasons for exemption in such application.
- (2) The Council may grant an exemption –
 - (a) in general or in particular;

(b) for any period; and

(c) subject to any condition that will provide the same overall fire prevention and protection that would result from the full application of these By-laws.

(3) If an exemption is granted in terms of subsection (2), the Council must issue a certificate of exemption to the person concerned, specifying the scope and period of the exemption and any condition imposed.

(4) The Council may amend or withdraw a certificate of exemption at any time.

(5) The holder of a certificate of exemption must ensure that the certificate is available on the premises concerned at all times for inspection by any member.

Approval, authorization or permission under these by-laws

104. Any person who requires any approval, authorization or permission contemplated in these By-laws, in respect of which no application procedure is provided, must apply for that approval, authorization or permission -

(a) by completing and submitting an application in the form and manner determined by the Council; and

(b) by paying the prescribed fee.

108. Cancellation of approval, authorization or permission

The provisions of section 24, read with the necessary changes, apply to any approval, authorization or permission contemplated in section 104.

109. By-laws bind State

These By-laws bind the State and any person in the service of the State.

110. Offences and penalties

(1) Any person who –

(a) contravenes or fails to comply with any provision of these by-laws;

(b) fails to comply with any notice issued or displayed in terms of these By-laws;

(c) fails to comply with any lawful instruction given in terms of these By-laws; or

2. is guilty of an offence and liable on conviction to punishment of a fine not exceeding R5 000 or imprisonment for a period not exceeding six months.

(3.) and in the case of a continuing offence, or Any person who-

(a) intentionally resists or obstructs a member of a service, including a chief fire officer, in the exercise of his execution of his or her duties or performance of his or her powers or functions under these By-laws;

(b) refuses or fails to comply with an order contemplated in section 14 (1);

(c) refuses or fails to carry out an instruction from the Chief Fire Officer contemplated in section 18 (2) within the period mentioned therein; or

(d) summons a service while he knows that there is no reason to do so,

shall be guilty of an offence, and on conviction liable to a fine not exceeding R10 000 or to imprisonment for a period not exceeding 12 months.

5. The Chief fire Officer will issue a notice to the owner for noncompliance and after three attempt the owner or the occupier will be guilty as charge and subsection (2) or subsection (3) will come into force.

111. Emergency exits and dangerous building /areas

Fire Chief Officer may recommend the building to be evacuated as soon as possible if he assumes that,

- a. the building may endanger human lives until proven by the structure engineer
- b. Or the emergency exit burgled or permanent locked

113. Repeal of by-laws

The by-laws listed in Schedule 5 are hereby repealed.

114. Short title

This By-law is called the Fire Brigade By-Law, 2016.

SCHEDULE 1

GUIDELINE FOR EMERGENCY EVACUATION PLANS

These guidelines refer to specifications in the Labor Act., and the Occupational Health and Safety Act. Provisions and prohibitions of the aforementioned acts is therefore relevant as well as the relevant fines and penalties.

Any person who fails to comply with the provisions of this section will be guilty of an offence.

1. Content of emergency evacuation plans

Every emergency evacuation plan contemplated in section 17 must contain at least the information under the headings below.

(a) Emergency telephone numbers

(b) A list of all relevant emergency telephone numbers.

(2) General information

(a) the physical address of the premises;

(b) a description of the activities on the premises;

(c) the number of persons present on the premises at any time;

(d) an indication of any control room on the premises;

- (e) an indication of any alarm system on the premises; and
- (f) the particulars and contact details of every responsible person in the event of an emergency;

(3) Area study

An area study addressing the following:

- (a) a history of emergency incidents on the premises;
- (b) any important and relevant features or landmarks regarding the premises; and
- (c) any information regarding adjacent premises that may be relevant to evacuation in an emergency.

(4) Socio-economic or other threats

Any socio-economic or other threats and their potential impact on the premises.

(5) Details of available equipment

Particulars and details regarding the position of the following equipment:

- (a) Equipment in the control room;
- (b) firefighting and first aid equipment on the premises; and
- (c) any other equipment which may be relevant in an emergency.

(6) The emergency team

Particulars and details regarding the identity of members of the emergency team, including -

- (a) its management;
- (b) the continuity officers;
- (c) the fire teams; and
- (d) the first aid teams.

(7) Duties of emergency team members

The duties and responsibilities of members of the emergency team.

(8) Action plans and emergency procedures

Details of the specific action plans and emergency procedures applicable to the premises.

(9) Building plans and maps

The building plans of the premises and any relevant topographical map must be included in the evacuation plan.

(10) Emergency plan register

The plan must include –

- (a) an updated register of the emergency evacuation plan;
- (b) an updated drill register for the emergency evacuation plan; and
- (c) a bomb threat questionnaire.

Review of emergency evacuation plans

2. (1) An emergency evacuation plan must be reviewed and updated by the owner or occupier or an appointed Health and Safety Consultant of the premises concerned at least once each year and whenever a member of the management of the emergency team ceases to work at the premises.

(2) Whenever an emergency evacuation plan is reviewed and updated, the owner or occupier or an appointed Health and Safety Consultant of the premises concerned must ensure that all old plans on the premises or in the possession of the management of the emergency team are collected and destroyed in order to eliminate any confusion regarding the validity and accuracy of the evacuation plan.

Emergency evacuation drills

3. (1) An emergency evacuation plan should be drilled at least twice each year as per stipulation in the Labor Act., the Health and Safety Act., and should involve the participation of all persons who work or reside in the building concerned.

(2) The owner or person in charge of a building should give all persons who are to be involved in an emergency evacuation drill at least 21 days' notice of the drill.

Emergency evacuation awareness

4. Every person who works or resides on premises should be aware of the emergency evacuation plan for that premises.

Training of persons

5. Every person who resides or works on premises with an emergency evacuation plan should be suitably trained in -

- (a) first aid or fire fighting;
- (b) emergency aid;
- (c) emergency evacuation procedures; and
- (d) emergency management techniques.

SCHEDULE 2

EXEMPTION FROM CERTIFICATE OF REGISTRATION

A certificate of registration is in terms of section 35(2) not required if the flammable substances concerned are of a type and do not exceed the quantity stipulated below.

GASES		
Class O	Liquefied petroleum gas	Flat- Total cylinder capacity may not exceed 9 kg per flat Houses or commercial premises- Total maximum of 19 kg inside and total maximum of 100 kg on premises Industrial premises- Maximum of 19 kg per 600 m ³ of building space with a total maximum of 100 kg
FLAMMABLE LIQUIDS AND COMBUSTIBLE LIQUIDS		
Class I	Liquids that have a closed-cap flash point of below 38 °C	Total maximum of 40 litres
Class II	Liquids that have a closed-cap flash point of 38 °C or above, but below 60.5 °C	Total quantity of Class II and Class IIIA together may not exceed the maximum quantity of 210 litres
Class IIIA		Liquids that have a close-cap flash point of 60.5 °C or above but below 93 °C

SCHEDULE 3

EXEMPTION FROM TRANSPORT PERMIT

A transport permit is in terms of section 73 not required for the transport of dangerous goods of the type and not exceeding the quantity stipulated below.

GROUP	DESCRIPTION	QUANTITY
II	GASES	
Flammable gases	Total cylinder capacity may not exceed 50 kilograms	
Non-flammable gases	Total cylinder capacity may not exceed 333 kilograms	
III	FLAMMABLE LIQUIDS	
With flash points ≤ 18oC	Total quantity may not exceed 100 liters	
With flash points > 18oC but ≤ 23oC	Total quantity may not exceed 420 liters	
With flash points > 23oC but ≤ 61oC	Total quantity may not exceed 1100 liters	
With flash points > 61oC but ≤ 100oC	Total quantity may not exceed 1 100 liters	
IV	FLAMMABLE SOLIDS	
Flammable solids	Total quantity may not exceed 250 kg	
V	OXIDISING AGENTS AND ORGANIC PEROXIDES	
Oxidizing agents	Total quantity may not exceed 200 kilograms	
Group II organic peroxides in packets	Total quantity may not exceed 200 kilograms	

VI	TOXIC / INFECTIVE SUBSTANCES
Group I toxic substances in packets	Total quantity may not exceed 5 kilograms
Group II toxic substances in packets	Total quantity may not exceed 50 kilograms
Group III toxic substances in packets	Total quantity may not exceed 500 kilograms
VIII	CORROSIVE / CAUSTIC SUBSTANCES
Group I acids in packets	Total quantity may not exceed 50 kilograms
Group II acids in packets	Total quantity may not exceed 200 kilograms
Group III acids in packets	Total quantity may not exceed 1000 kilograms
Group I alkaline substances in packets	Total quantity may not exceed 50 kilograms
Group II alkaline substances in packets	Total quantity may not exceed 200 kilograms
IX	MISCELLANEOUS SUBSTANCES
Liquids	Total quantity may not exceed 210 liters
Solids	Total quantity may not exceed 210 kilograms

SCHEDULE 4

SANS CODES OF PRACTICE AND SPECIFICATIONS

SANS Code	Title
SANS 019	Portable metal containers for compressed gas - basic design, manufacture, use and maintenance.
SANS 087 : Part 1	The handling, storage and distribution of liquefied petroleum gas in domestic, commercial and industrial installations, Part 1: Liquefied petroleum gas installations involving gas storage containers of individual water capacity not exceeding 500l and a combined water capacity not exceeding 3000l per installation.
SANS 087 : Part 3	The handling, storage and distribution of liquefied petroleum gas in domestic, commercial and industrial installations, Part 3: Liquefied petroleum gas installations involving storage vessels of individual water capacity exceeding 5000l.
SANS 087 : Part 4	The handling, storage and distribution of liquefied petroleum gas in domestic, commercial and industrial installations, Part 4: Transportation of liquefied petroleum gas in bulk by road.
SANS 087 : Part 7	The handling, storage and distribution of liquefied petroleum gas in domestic, commercial and industrial installations, Part 7: Storage and filling sites for refillable liquefied petroleum gas (LPG) containers of capacity not exceeding 9 kg.

SANS 089 : Part 1	The petroleum industry, Part 1: Storage and distribution of petroleum products in above ground bulk installations.
SANS 089 : Part 2	The petroleum industry, Part 2: Electrical installations in the distribution and marketing sector.
SANS 0105 : Part 1	The classification, use and control of firefighting equipment, Part 1: Portable fire extinguishers.
SANS 0108	The classification of hazardous locations and the selection of apparatus for use in such locations.
SANS 0131	The handling and storage of liquid fuel, Part 2: Large consumer premises.
SANS 0142	The wiring of premises.
SANS 0177 : Part 5	The testing of materials, components and elements used in buildings: Non-combustibility at 750oC of building materials.
SANS 193	Fire dampers.
SANS 0228	The identification and classification of dangerous substances and goods.
SANS 0230	Transportation of dangerous goods: Inspection requirements of road vehicles.
SANS 0232 : Part 1	Transportation of dangerous goods - Emergency information systems, Part 1: Emergency information systems for road

SCHEDULE 5

REPEALED BY-LAWS

Number and Year	Name of By-laws	Extent of Repeal
Administrator's Notice 1771 dated 23 December, 1981	Nelspruit Town Council Standard by-laws relating to fire brigade services	Whole
Administrator's Notice 597 dated 11 April, 1973	White river municipality: fire brigade by-laws	Whole
Administrator's Notice 2261 dated 3 December, 1986	Barberton municipality: Fire Brigade by-laws	Whole

PROVINCIAL NOTICE 53 OF 2021**STEVE TSHWETE AMENDMENT SCHEME 16, ANNEXURE A16****NOTICE OF APPLICATION FOR THE AMENDMENT OF THE STEVE TSHWETE LAND USE SCHEME, 2019 IN TERMS OF SECTIONS 62(1) AND 94(1)(A) OF THE STEVE TSHWETE SPATIAL PLANNING AND LAND USE MANAGEMENT BYLAW, 2016.**

I, Jaco Peter le Roux, of Afriplan CC being the authorized agent of the owner of **Erf 1443, Middelburg X4** hereby give notice in terms of Section 94(1)(a) of the Steve Tshwete Spatial Planning and Land Use Management Bylaw, 2016, that I have applied to the Steve Tshwete Local Municipality for the amendment of the town planning scheme known as the Steve Tshwete Land Use Scheme, 2019, for the rezoning of the Erf 1443, Middelburg X4 situated at 18 Protea Road, from “**Residential Zone 1**” to “**Residential Zone 3**”.

Full particulars and plans may be inspected during normal office hours at the office of the Municipal Manager, Steve Tshwete Local Municipality, Cnr. Walter Sisulu and Wanderers Avenue, Middelburg, 1050, Tel: 013 2497000, for a period of 30 days from **4 June 2021** (last day for comments being 5 July 2021). Any person who cannot write may during office hours attend the Office of the Municipal Manager, where an official will assist that person to lodge comment.

Any objection/s or comments including the grounds for such objection/s or comments with full contact details, shall be made in writing to the Municipal Manager, PO Box 14, Middelburg 1050 within 30 days from **4 June 2021**.

Details of agent: Afriplan CC, 14 John Magagula Street, Middelburg 1050. Tel: 013 282 8035 Fax: 013 243 1706. E-mail: jaco@afriplan.com/vicky@afriplan.com

4-11

PROVINSIALE KENNISGEWING 53 VAN 2021**STEVE TSHWETE WYSIGINGSKEMA 16, BYLAAG A16****KENNISGEWING VAN DIE AANSOEK OM DIE WYSIGING VAN DIE STEVE TSHWETE GRONDGEBRUIKSKEMA, 2019, INGEVOLGE ARTIKELS 62(1) EN 94(1)(A) VAN DIE STEVE TSHWETE RUIMTELIKE BEPLANNING EN GRONDGEBRUIKSBESTUURVERORDENING, 2016**

Ek, Jaco Peter le Roux, van Afriplan CC synde die gemagtigde agent van die eienaar van **Erf 1443, Middelburg X4** gee hiermee ingevolge Artikel 94(1)(a)) van die Steve Tshwete Ruimtelike Beplanning en Grondgebruiksbestuursverordening, 2016, kennis dat ons by Steve Tshwete Plaaslike Munisipaliteit aansoek gedoen het vir die wysiging van die Steve Tshwete Grondgebruikskema, 2019, deur die hersonering van Erf 1443, Middelburg X4, geleë te Proteaweg 18 vanaf “**Residensiël Sone 1**” na “**Residensiël Sone 3**”.

Besonderhede van die aansoek lê ter insae gedurende gewone kantoorure by die kantoor van die Munisipale Bestuurder, Steve Tshwete Plaaslike Munisipaliteit, Munisipale gebou, Wandererslaan, Middelburg, 1050, vir 'n tydperk van 30 dae vanaf **4 Junie 2021** (laaste datum vir kommentare 5 Julie 2021). Enige persoon wat nie kan skryf nie sal tydens kantoor-ure deur 'n amptenaar by die Kantoor van die Munisipale Bestuurder bygestaan word om kommentaar in te dien.

Besware of verhoë ten opsigte van die aansoek moet binne 'n tydperk van 30 dae vanaf **4 Junie 2021**, skriftelik by of tot die Munisipale Bestuurder by bovermelde adres of by Posbus 14, Middelburg, 1050, ingedien of gerig word.

Besonderhede van die agent: Afriplan CC, John Magagulastraat 14, Middelburg 1050. Tel: 013 282 8035 Faks: 013 243 1706. E-pos: : jaco@afriplan.com/vicky@afriplan.com

4-11

PROVINCIAL NOTICE 54 OF 2021
STEVE TSHWETE AMENDMENT SCHEME No. 22

NOTICE OF APPLICATION FOR THE AMENDMENT OF THE STEVE TSHWETE TOWN PLANNING SCHEME, 2004, IN TERMS OF SECTION 62(1) AND 94(1) (A) OF THE STEVE TSHWETE SPATIAL PLANNING AND LAND USE MANAGEMENT BYLAW, 2016.

I/we **Nomfundo Skhosana** being the authorized agent of the registered owner of **Erf/Erven 1276 Aerorand** hereby give notice in terms of **section 94(1)(a) of the Steve Tshwete Spatial Planning and Land Use Management Bylaw, 2016**, that I have applied to the Steve Tshwete Local Municipality for the amendment of the town planning scheme known as the Steve Tshwete Land Use Scheme, 2019, for the rezoning of the abovementioned property situated at (street address) 5 Tugela Street, by rezoning the property from **Residential 1 Zone** to **Residential 3 Zone** subject to certain conditions.

Any objection/s or comments including the grounds for such objection/s or comments with full contact details, shall be made in writing to the Municipal Manager, PO Box 14, Middelburg 1050 within 30 days from **04 JUNE 2021**.

Full particulars and plans may be inspected during normal office hours at the office of the Municipal Manager, Steve Tshwete Local Municipality, Cnr. Walter Sisulu and Wanderers Avenue, Middelburg, 1050, Tel: 013 2497000, for a period of 30 days from **04 JUNE 2021**.

Address of the Applicant: jalitownplanners@gmail.com

Telephone no: +27783866314.

4-11

PROVINSIALE KENNISGEWING 54 VAN 2021

STEVE TSHWETE WYSIGINGSKEMA No. 22

KENNISGEWING VAN DIE AANSOEK OM DIE WYSIGING VAN DIE STEVE TSHWETE DORPSBEPLANNINGSKEMA, 2019, IN TERME VAN ARTIKEL 62(1) EN 94(1)(a) VAN DIE STEVE TSHWETE RUIMTELIKE BEPLANNING EN GRONDGEBUIKBESTUUR BYWET, 2016

Ek/ Ons, **Nomfundo Skhosana**, synde die gemagtigde agent van die geregistreerde eienaar van **Erf/Erwe 1276 Aerorand**, gee hiermee in terme van Artikel **94(1)(a) van die Steve Tshwete Ruimtelike Beplanning en Grondgebruiksbestuur Bywet, 2016** kennis om die wysiging van Steve Tshewe Dorpsbeplanningskema, 2004, deur die hersonering van die bogenoemde eiendom geleë te **5 Tugela Straat**, vanaf, **Residensiële 1 sone** na **Residensiële 3 sone**, onderworpe aan sekere voorwaardes.

Enige beswaar of kommentaar insluitend gronde vir genoemde beswaar/ of kommentaar met volledige kontakbesonderhede, moet skriftelik binne 'n tydperk van 30 dae vanaf **04 JUNE 2021** aan die Munisipale Bestuurder, Posbus 14, Middelburg 1050, gerig word.

Volledige besonderhede en planne lê ter insae gedurende gewone kantoorure by die kantoor van die Munisipale Bestuurder, Steve Tshwete Plaaslike Munisipaliteit, H/v Walter Sisulu en Wandererslaan, Middelburg, 1050, Tel: 013 2497000 vir 'n tydperk van 30 dae vanaf **04 JUNE 2021**.

Adres van Applikant: Jalitownplanners@gmail.com

Tel no: +27783866314.

4-11

Printed by and obtainable from the Government Printer, Bosman Street, Private Bag X85, Pretoria, 0001.
Contact Centre Tel: 012-748 6200. eMail: info.egazette@gpw.gov.za
Publications: Tel: (012) 748 6053, 748 6061, 748 6065

Also available at the **Provincial Legislature: Mpumalanga**, Private Bag X11289, Room 114, Civic Centre Building,
Nel Street, Nelspruit, 1200. Tel. (01311) 5-2133.